

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
1/4/2019	3021 WAGON WHEEL	3.48	2.97	0.18	0.004	0.48	7.9	12.6
1/4/2019	FIREWHEEL PS	3.30	2.80	0.18	0.002	0.52	7.8	12.7
1/4/2019	498 CANTERBURY	3.20	2.77	0.17	0.003	0.46	7.8	14.1
1/4/2019	1902 PLEASANT VALLEY	2.92	2.64	0.23	0.004	0.42	7.8	15.5
1/4/2019	LAVON PS	3.31	3.05	0.13	0.003	0.49	7.8	14.2
1/4/2019	BROADWAY PS	3.18	2.95	0.14	0.003	0.45	7.8	12.7
1/4/2019	4301 BROADWAY	3.22	2.82	0.17	0.002	0.57	7.7	14.4
1/4/2019	5626 LYONS	2.99	2.59	0.39	0.004	0.54	7.8	14.8
1/4/2019	1538 E I30	2.86	2.45	0.22	0.004	0.42	7.8	15.8
1/4/2019	1426 COMMERCE	2.99	2.71	0.16	0.003	0.54	7.7	13.8
1/4/2019	COMMERCE TOWER	2.99	2.68	0.22	0.006	0.48	7.8	13.5
1/7/2019	APOLLO PS	3.18	3.00	0.15	0.005	0.80	8.0	14.9
1/7/2019	7602 N JUPITER	3.55	3.26	0.16	0.008	0.63	8.4	12.3
1/7/2019	1301 JUPITER	3.26	2.99	0.22	0.008	0.64	8.1	16.8
1/7/2019	2218 S JUPITER	2.94	2.61	0.25	0.008	0.56	7.8	17.0
1/7/2019	5013 SATURN	2.95	2.64	0.20	0.004	0.54	7.8	15.1
1/7/2019	119 BUCKINGHAM	2.81	2.48	0.21	0.005	0.72	7.9	16.3
1/7/2019	WALLACE PS	3.42	3.11	0.14	0.004	0.78	8.0	12.1
1/7/2019	1980 FOREST	3.22	2.86	0.20	0.005	0.75	8.1	16.4
1/7/2019	FOREST TOWER	3.29	2.94	0.40	0.005	0.73	7.9	14.5
1/7/2019	LAWLER TOWER	3.31	2.90	0.16	0.004	0.68	7.9	14.0
1/8/2019	3021 WAGON WHEEL	3.45	3.27	0.16	0.009	0.50	8.5	15.5
1/8/2019	FIREWHEEL PS	3.26	3.10	0.15	0.005	0.48	8.1	12.9
1/8/2019	498 CANTERBURY	3.04	2.80	0.18	0.004	0.49	8.0	13.9
1/8/2019	1902 PLEASANT VALLEY	3.05	2.82	0.19	0.007	0.50	8.0	15.9
1/8/2019	LAVON PS	3.51	3.19	0.14	0.007	0.54	8.3	13.0
1/8/2019	BROADWAY PS	3.20	2.97	0.15	0.005	0.53	8.1	13.9
1/8/2019	4301 BROADWAY	3.13	3.05	0.13	0.005	0.51	8.0	13.5
1/8/2019	5626 LYONS	2.89	2.79	0.15	0.005	0.48	7.9	15.0
1/8/2019	1538 E I30	2.77	2.62	0.19	0.005	0.48	7.9	16.1
1/8/2019	1426 COMMERCE	3.15	2.96	0.16	0.007	0.49	8.1	14.5
1/8/2019	COMMERCE TOWER	3.12	2.91	0.15	0.005	0.52	8.0	13.7
1/11/2019	APOLLO PS	3.65	3.17	0.17	0.003	0.51	7.8	12.7

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
1/11/2019	WALLACE PS	3.48	3.30	0.13	0.005	0.48	8.1	14.1
1/11/2019	FOREST TOWER	3.10	2.91	0.17	0.005	0.53	8.1	13.3
1/11/2019	LAWLER TOWER	3.63	3.26	0.16	0.003	0.48	7.9	12.3
1/11/2019	FIREWHEEL PS	3.38	3.23	0.19	0.005	0.52	8.0	14.7
1/11/2019	LAVON PS	3.41	3.40	0.13	0.007	0.46	8.3	13.1
1/11/2019	BROADWAY PS	3.08	2.85	0.19	0.006	0.41	8.1	18.3
1/11/2019	COMMERCE TOWER	3.23	3.12	0.20	0.006	0.49	8.2	13.7
1/14/2019	APOLLO PS	3.78	3.54	0.03	0.008	0.49	8.1	12.9
1/14/2019	7602 N JUPITER	3.40	3.17	0.14	0.006	0.53	8.1	14.8
1/14/2019	1301 JUPITER	3.37	3.25	0.07	0.007	0.45	8.1	15.8
1/14/2019	2218 S JUPITER	2.10	2.00	0.33	0.011	0.42	8.0	16.5
1/14/2019	5013 SATURN	3.24	2.99	0.17	0.006	0.46	8.1	14.2
1/14/2019	119 BUCKINGHAM	3.15	2.90	0.16	0.007	0.47	8.1	14.5
1/14/2019	WALLACE PS	3.60	3.25	0.09	0.005	0.47	8.1	13.4
1/14/2019	1980 FOREST	3.14	3.20	0.11	0.006	0.48	8.1	14.6
1/14/2019	FOREST TOWER	3.25	2.97	0.28	0.006	0.51	8.0	13.8
1/14/2019	LAWLER TOWER	3.45	3.37	0.07	0.005	0.46	8.1	13.2
1/15/2019	3021 WAGON WHEEL	3.63	3.34	0.13	0.006	0.53	8.2	14.1
1/15/2019	FIREWHEEL PS	3.38	3.21	0.17	0.003	0.51	8.0	12.3
1/15/2019	498 CANTERBURY	3.16	3.08	0.16	0.004	0.45	8.0	14.1
1/15/2019	1902 PLEASANT VALLEY	2.83	2.69	0.21	0.005	0.46	8.1	16.3
1/15/2019	LAVON PS	3.20	3.02	0.17	0.004	0.45	8.1	14.7
1/15/2019	BROADWAY PS	3.27	2.93	0.22	0.005	0.43	8.3	12.3
1/15/2019	4301 BROADWAY	3.23	3.11	0.15	0.007	0.56	8.1	14.0
1/15/2019	5626 LYONS	3.01	2.92	0.16	0.005	0.50	8.1	14.6
1/15/2019	1538 E I30	2.87	2.65	0.27	0.007	0.47	8.1	15.4
1/15/2019	1426 COMMERCE	3.22	3.04	0.16	0.007	0.43	8.1	13.0
1/15/2019	COMMERCE TOWER	3.25	3.03	0.15	0.005	0.50	8.1	13.0
1/22/2019	APOLLO PS	3.62	3.33	0.09	0.005	0.43	8.1	12.5
1/22/2019	7602 N JUPITER	3.37	3.06	0.10	0.004	0.45	7.9	13.9
1/22/2019	1301 JUPITER	3.08	2.74	0.21	0.007	0.47	7.9	16.6
1/22/2019	2218 S JUPITER	2.95	2.37	0.23	0.008	0.44	7.9	15.2
1/22/2019	5013 SATURN	3.08	2.71	0.24	0.007	0.45	8.1	14.6

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
1/22/2019	119 BUCKINGHAM	3.11	2.69	0.24	0.005	0.46	8.0	14.7
1/22/2019	WALLACE PS	3.47	3.04	0.13	0.003	0.40	8.0	12.5
1/22/2019	1980 FOREST	3.29	2.80	0.17	0.004	0.46	8.0	15.2
1/22/2019	FOREST TOWER	3.31	2.90	0.23	0.004	0.55	7.8	15.3
1/22/2019	LAWLER TOWER	3.57	3.20	0.12	0.005	0.50	8.0	13.5
1/24/2019	3021 WAGON WHEEL	3.28	2.91	0.15	0.008	0.55	8.2	14.9
1/24/2019	FIREWHEEL PS	3.26	3.15	0.10	0.004	0.45	8.1	12.1
1/24/2019	498 CANTERBURY	3.16	3.03	0.13	0.005	0.50	8.0	15.0
1/24/2019	1902 PLEASANT VALLEY	2.73	2.57	0.21	0.007	0.58	8.1	16.3
1/24/2019	LAVON PS	3.31	3.11	0.16	0.007	0.48	8.2	13.6
1/24/2019	BROADWAY PS	2.42	2.32	0.28	0.008	0.49	8.2	19.1
1/24/2019	4301 BROADWAY	3.09	2.99	0.14	0.005	0.50	8.1	13.7
1/24/2019	1538 E I30	2.74	2.54	0.21	0.006	0.40	8.1	15.4
1/24/2019	1426 COMMERCE	3.18	2.74	0.20	0.002	0.41	8.2	13.1
1/24/2019	COMMERCE TOWER	3.18	2.90	0.18	0.005	0.43	8.2	12.9
1/28/2019	APOLLO PS	3.35	3.27	0.06	0.006	0.51	8.1	13.6
1/28/2019	7602 N JUPITER	3.20	3.05	0.10	0.006	0.59	8.1	14.2
1/28/2019	1301 JUPITER	2.97	2.87	0.12	0.007	0.53	8.0	18.1
1/28/2019	2218 S JUPITER	2.73	2.54	0.13	0.010	0.52	8.1	18.2
1/28/2019	5013 SATURN	2.90	2.39	0.19	0.006	0.37	8.1	13.7
1/28/2019	119 BUCKINGHAM	2.86	2.60	0.14	0.008	0.44	8.0	16.6
1/28/2019	WALLACE PS	3.16	2.78	0.18	0.005	0.43	8.1	11.6
1/28/2019	1980 FOREST	3.15	2.93	0.13	0.006	0.55	8.1	13.6
1/28/2019	FOREST TOWER	3.29	2.87	0.12	0.006	0.43	8.1	13.3
1/28/2019	LAWLER TOWER	3.35	3.08	0.09	0.007	0.54	8.1	13.7
1/29/2019	3021 WAGON WHEEL	3.50	3.14	0.15	0.005	0.46	8.0	14.8
1/29/2019	FIREWHEEL PS	3.33	3.03	0.16	0.004	0.35	8.1	12.7
1/29/2019	498 CANTERBURY	3.12	3.01	0.13	0.005	0.44	8.1	13.3
1/29/2019	1902 PLEASANT VALLEY	2.83	2.65	0.15	0.007	0.41	8.1	15.2
1/29/2019	LAVON PS	3.31	3.04	0.13	0.006	0.39	8.1	13.5
1/29/2019	BROADWAY PS	3.07	2.97	0.14	0.004	0.41	8.0	12.9
1/29/2019	4301 BROADWAY	3.00	2.87	0.17	0.004	0.43	7.9	17.3
1/29/2019	1538 E I30	2.67	2.57	0.17	0.007	0.50	8.0	16.6

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
1/29/2019	1426 COMMERCE	2.99	2.75	0.13	0.006	0.39	8.1	13.3
1/29/2019	COMMERCE TOWER	3.15	2.89	0.26	0.005	0.40	8.1	12.9
2/1/2019	APOLLO PS	3.66	3.27	0.12	0.006	0.50	8.2	11.7
2/1/2019	WALLACE PS	3.57	3.24	0.13	0.008	0.46	8.2	11.1
2/1/2019	FOREST TOWER	3.64	3.26	0.14	0.007	0.44	8.2	13.7
2/1/2019	LAWLER TOWER	3.57	3.52	0.06	0.009	0.42	8.3	12.8
2/1/2019	FIREWHEEL PS	3.45	3.10	0.18	0.004	0.46	8.0	12.7
2/1/2019	LAVON PS	3.46	3.11	0.19	0.005	0.43	8.2	11.7
2/1/2019	BROADWAY PS	3.35	3.23	0.15	0.006	0.44	8.2	12.5
2/1/2019	COMMERCE TOWER	3.25	2.96	0.23	0.006	0.47	8.1	13.2
2/4/2019	APOLLO PS	3.63	3.23	0.16	0.007	0.45	8.3	13.8
2/4/2019	7602 N JUPITER	3.51	3.06	0.19	0.004	0.46	7.9	14.5
2/4/2019	1301 JUPITER	3.30	3.02	0.20	0.008	0.47	8.1	17.8
2/4/2019	2218 S JUPITER	3.07	2.70	0.25	0.008	0.40	8.0	16.6
2/4/2019	5013 SATURN	3.17	2.90	0.20	0.007	0.43	8.0	16.1
2/4/2019	119 BUCKINGHAM	3.27	2.92	0.24	0.006	0.49	8.1	15.2
2/4/2019	WALLACE PS	3.55	3.23	0.16	0.006	0.50	8.0	14.4
2/4/2019	1980 FOREST	3.38	2.98	0.22	0.005	0.41	8.0	15.8
2/4/2019	FOREST TOWER	3.29	3.06	0.16	0.005	0.43	7.9	16.9
2/4/2019	LAWLER TOWER	3.38	3.10	0.24	0.004	0.40	8.0	14.3
2/6/2019	3021 WAGON WHEEL	3.56	3.30	0.16	0.008	0.40	8.3	15.6
2/6/2019	FIREWHEEL PS	3.36	3.17	0.18	0.006	0.43	8.2	14.4
2/6/2019	498 CANTERBURY	3.33	3.00	0.19	0.007	0.39	8.2	14.3
2/6/2019	1902 PLEASANT VALLEY	3.01	2.68	0.22	0.008	0.37	8.1	15.8
2/6/2019	LAVON PS	3.33	3.19	0.18	0.007	0.49	8.2	14.6
2/6/2019	BROADWAY PS	3.29	3.09	0.17	0.006	0.47	8.2	14.0
2/6/2019	4301 BROADWAY	3.22	3.04	0.20	0.007	0.44	8.2	14.7
2/6/2019	1538 E I30	3.04	2.76	0.22	0.009	0.45	8.2	16.9
2/6/2019	1426 COMMERCE	3.09	2.93	0.21	0.007	0.46	8.2	15.5
2/6/2019	COMMERCE TOWER	3.14	2.85	0.20	0.006	0.44	8.2	15.9
2/8/2019	APOLLO PS	3.56	3.20	0.11	0.007	0.39	8.4	12.0
2/8/2019	WALLACE PS	3.58	3.34	0.15	0.006	0.40	8.4	12.8
2/8/2019	FOREST TOWER	3.49	3.21	0.17	0.008	0.43	8.3	13.7

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
2/8/2019	LAWLER TOWER	3.60	3.35	0.12	0.007	0.37	8.4	11.8
2/8/2019	FIREWHEEL PS	3.53	3.19	0.17	0.007	0.41	8.3	11.8
2/8/2019	LAVON PS	3.49	3.32	0.14	0.007	0.38	8.3	12.2
2/8/2019	BROADWAY PS	3.33	3.11	0.18	0.006	0.41	8.2	12.4
2/8/2019	COMMERCE TOWER	3.29	3.04	0.20	0.007	0.44	8.3	12.8
2/12/2019	APOLLO PS	3.36	3.13	0.12	0.006	0.51	8.2	12.5
2/12/2019	7602 N JUPITER	3.23	2.93	0.17	0.008	0.52	8.3	14.5
2/12/2019	1301 JUPITER	2.91	2.64	0.18	0.009	0.56	8.1	17.5
2/12/2019	2218 S JUPITER	2.97	2.73	0.16	0.009	0.51	8.2	16.7
2/12/2019	5013 SATURN	3.10	2.68	0.17	0.008	0.54	8.2	14.9
2/12/2019	119 BUCKINGHAM	2.94	2.71	0.19	0.007	0.48	8.2	15.4
2/12/2019	WALLACE PS	3.25	3.06	0.11	0.007	0.53	8.2	12.7
2/12/2019	1980 FOREST	3.29	2.95	0.21	0.007	0.59	8.2	15.5
2/12/2019	FOREST TOWER	3.23	3.02	0.16	0.007	0.51	8.2	14.5
2/12/2019	LAWLER TOWER	3.21	3.01	0.13	0.006	0.55	8.2	12.9
2/14/2019	3021 WAGON WHEEL	3.45	3.17	0.17	0.006	0.53	8.2	15.1
2/14/2019	FIREWHEEL PS	3.27	3.07	0.13	0.006	0.48	8.2	12.6
2/14/2019	498 CANTERBURY	3.24	3.05	0.20	0.006	0.56	8.2	13.8
2/14/2019	1902 PLEASANT VALLEY	2.85	2.59	0.28	0.007	0.59	8.2	16.1
2/14/2019	LAVON PS	3.32	3.26	0.11	0.006	0.47	8.2	14.8
2/14/2019	BROADWAY PS	3.24	3.18	0.22	0.006	0.58	8.1	13.4
2/14/2019	4301 BROADWAY	3.07	3.02	0.12	0.006	0.59	8.2	14.1
2/14/2019	5626 LYONS	2.83	2.74	0.34	0.007	0.52	8.2	16.6
2/14/2019	1538 E I30	2.82	2.71	0.20	0.009	0.51	8.2	15.4
2/14/2019	1426 COMMERCE	3.19	3.12	0.21	0.007	0.50	8.2	14.7
2/14/2019	COMMERCE TOWER	3.04	2.96	0.14	0.007	0.55	8.2	13.7
2/15/2019	APOLLO PS	3.48	3.34	0.19	0.004	0.47	7.9	14.1
2/15/2019	WALLACE PS	3.42	3.35	0.14	0.004	0.47	8.1	14.1
2/15/2019	FOREST TOWER	3.32	3.22	0.12	0.006	0.52	8.1	15.4
2/15/2019	LAWLER TOWER	3.30	3.16	0.42	0.005	0.56	8.1	13.4
2/15/2019	FIREWHEEL PS	3.30	3.19	0.16	0.007	0.46	8.1	13.4
2/15/2019	LAVON PS	3.36	3.26	0.16	0.005	0.44	8.2	12.8
2/15/2019	BROADWAY PS	3.26	3.21	0.11	0.004	0.57	8.2	14.2

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
2/15/2019	COMMERCE TOWER	3.15	3.02	0.14	0.006	0.53	8.2	14.0
2/18/2019	APOLLO PS	3.33	3.22	0.22	0.005	0.48	8.0	12.6
2/18/2019	7602 N JUPITER	3.53	3.32	0.14	0.006	0.52	8.1	13.9
2/18/2019	1301 JUPITER	2.67	2.55	0.27	0.008	0.47	8.0	17.0
2/18/2019	2218 S JUPITER	3.13	3.00	0.17	0.009	0.51	8.1	14.9
2/18/2019	5013 SATURN	3.17	3.07	0.19	0.006	0.48	8.3	14.5
2/18/2019	119 BUCKINGHAM	3.21	3.04	0.15	0.009	0.46	8.3	14.4
2/18/2019	WALLACE PS	3.41	3.24	0.12	0.008	0.49	8.2	12.2
2/18/2019	1980 FOREST	3.42	3.14	0.13	0.008	0.51	8.2	13.8
2/18/2019	FOREST TOWER	3.30	3.04	0.14	0.008	0.55	8.3	10.6
2/18/2019	LAWLER TOWER	3.45	3.18	0.16	0.005	0.51	8.1	11.9
2/19/2019	3021 WAGON WHEEL	3.64	3.31	0.11	0.015	0.49	8.1	14.5
2/19/2019	FIREWHEEL PS	3.24	3.19	0.12	0.014	0.51	8.3	12.1
2/19/2019	498 CANTERBURY	3.21	3.16	0.12	0.012	0.48	8.3	13.2
2/19/2019	1902 PLEASANT VALLEY	2.98	2.99	0.12	0.018	0.56	8.2	14.8
2/19/2019	LAVON PS	3.18	3.16	0.08	0.018	0.49	8.2	13.1
2/19/2019	BROADWAY PS	3.04	3.08	0.11	0.019	0.52	8.2	12.7
2/19/2019	4301 BROADWAY	3.04	2.94	0.17	0.018	0.52	8.2	13.4
2/19/2019	5626 LYONS	2.87	2.81	0.16	0.013	0.60	8.2	14.9
2/19/2019	1538 E I30	2.83	2.83	0.14	0.021	0.49	8.2	15.9
2/19/2019	1426 COMMERCE	3.04	3.02	0.13	0.015	0.50	8.2	13.8
2/19/2019	COMMERCE TOWER	3.14	3.09	0.14	0.024	0.49	8.2	13.1
2/22/2019	APOLLO PS	3.49	3.45	0.10	0.013	0.59	8.1	11.2
2/22/2019	WALLACE PS	3.36	3.02	0.15	0.008	0.56	7.8	10.8
2/22/2019	FOREST TOWER	3.49	3.27	0.09	0.006	0.55	8.1	12.7
2/22/2019	LAWLER TOWER	3.32	3.30	0.10	0.016	0.57	8.0	11.5
2/22/2019	FIREWHEEL PS	3.34	3.29	0.12	0.011	0.59	8.1	11.2
2/22/2019	LAVON PS	3.29	3.04	0.13	0.000	0.52	8.0	11.9
2/22/2019	BROADWAY PS	3.27	3.00	0.13	0.009	0.66	8.0	11.5
2/22/2019	COMMERCE TOWER	3.18	3.01	0.14	0.015	0.56	8.2	12.3
2/26/2019	APOLLO PS	3.58	3.52	0.05	0.012	0.44	8.2	12.7
2/26/2019	7602 N JUPITER	2.45	3.31	0.06	0.018	0.52	8.2	13.9
2/26/2019	1301 JUPITER	2.81	2.83	0.16	0.019	0.57	8.1	17.4

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
2/26/2019	2218 S JUPITER	3.26	3.10	0.12	0.024	0.50	8.2	15.2
2/26/2019	5013 SATURN	3.29	3.14	0.14	0.013	0.47	8.1	15.1
2/26/2019	119 BUCKINGHAM	3.27	3.15	0.11	0.019	0.64	8.2	15.2
2/26/2019	WALLACE PS	3.63	3.42	0.09	0.011	0.47	8.2	12.1
2/26/2019	1980 FOREST	3.28	3.17	0.14	0.017	0.52	8.3	15.0
2/26/2019	FOREST TOWER	3.24	3.20	0.11	0.012	0.48	8.2	13.9
2/26/2019	LAWLER TOWER	3.46	3.34	0.09	0.018	0.51	8.2	13.3
2/28/2019	3021 WAGON WHEEL	3.60	3.47	0.08	0.015	0.49	8.2	14.7
2/28/2019	FIREWHEEL PS	3.33	3.31	0.08	0.013	0.45	8.2	12.8
2/28/2019	498 CANTERBURY	3.27	3.19	0.11	0.013	0.45	8.2	13.7
2/28/2019	1902 PLEASANT VALLEY	3.01	2.99	0.13	0.020	0.49	8.2	14.8
2/28/2019	LAVON PS	3.31	3.27	0.09	0.011	0.45	8.3	14.7
2/28/2019	BROADWAY PS	3.09	3.06	0.12	0.012	0.49	8.1	16.3
2/28/2019	4301 BROADWAY	3.21	3.17	0.23	0.014	0.44	8.2	13.5
2/28/2019	5626 LYONS	2.99	2.95	0.12	0.020	0.42	8.2	14.9
2/28/2019	1538 E I30	2.96	2.89	0.13	0.013	0.47	8.2	15.2
2/28/2019	1426 COMMERCE	2.90	2.89	0.22	0.019	0.42	8.2	13.8
2/28/2019	COMMERCE TOWER	3.00	2.99	0.13	0.014	0.51	8.2	13.8
3/4/2019	APOLLO PS	3.78	3.52	0.10	0.019	0.55	8.4	10.7
3/4/2019	7602 N JUPITER	3.57	3.22	0.12	0.017	0.53	8.0	13.2
3/4/2019	1301 JUPITER	3.45	3.18	0.12	0.013	0.49	7.9	15.3
3/4/2019	2218 S JUPITER	3.37	3.15	0.12	0.016	0.50	7.9	13.9
3/4/2019	119 BUCKINGHAM	3.17	2.89	0.13	0.014	0.56	8.0	14.2
3/4/2019	WALLACE PS	3.61	3.34	0.09	0.008	0.56	8.0	11.0
3/4/2019	1980 FOREST	3.48	3.22	0.11	0.012	0.50	8.0	13.6
3/4/2019	FOREST TOWER	3.52	3.20	0.12	0.014	0.55	8.0	12.9
3/4/2019	LAWLER TOWER	3.31	3.25	0.11	0.008	0.43	8.0	9.7
3/5/2019	3021 WAGON WHEEL	3.45	3.25	0.06	0.012	0.57	8.4	13.5
3/5/2019	FIREWHEEL PS	1.11	0.64	0.00	0.010	0.48	8.6	9.8
3/5/2019	498 CANTERBURY	3.41	3.16	0.13	0.013	0.47	8.2	12.0
3/5/2019	1902 PLEASANT VALLEY	3.13	2.97	0.14	0.014	0.59	8.1	13.7
3/5/2019	BROADWAY PS	1.70	1.46	0.00	0.006	0.53	8.1	11.6
3/5/2019	4301 BROADWAY	2.07	1.93	0.03	0.010	0.52	8.1	11.5

City of Garland Water Quality Samples
January 4, 2019 – Present

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
3/5/2019	5626 LYONS	3.12	2.85	0.15	0.013	0.51	8.0	13.8
3/5/2019	1538 E I30	3.10	2.89	0.15	0.010	0.53	8.0	14.3
3/5/2019	1426 COMMERCE	3.19	2.97	0.11	0.008	0.56	8.0	11.3
3/6/2019	APOLLO PS	3.61	0.01	0.02	0.008	0.00	7.8	13.4
3/6/2019	WALLACE PS	1.82	0.00	0.02	0.010	0.00	8.1	11.3
3/6/2019	FOREST TOWER	2.63	0.03	0.00	0.003	0.00	8.0	12.1
3/6/2019	LAWLER TOWER	0.98	0.00	0.01	0.007	0.00	8.0	10.3
3/6/2019	FIREWHEEL PS	1.99	0.00	0.00	0.007	0.00	8.0	9.6
3/6/2019	BROADWAY PS	2.11	0.00	0.00	0.009	0.00	8.1	10.7
3/7/2019	APOLLO PS	3.95	0.03	0.02	0.004	0.57	7.7	10.9
3/7/2019	7602 N JUPITER	3.32	0.05	0.02	0.003	0.59	7.9	13.1
3/7/2019	1301 JUPITER	2.19	0.01	0.00	0.002	0.51	7.9	16.4
3/7/2019	2218 S JUPITER	2.55	0.02	0.05	0.003	0.54	7.9	13.9
3/7/2019	119 BUCKINGHAM	2.86	0.03	0.27	0.003	0.59	8.0	13.1
3/7/2019	WALLACE PS	3.24	0.02	0.03	0.004	0.54	7.9	10.5
3/7/2019	1980 FOREST	2.45	0.00	0.00	0.002	0.48	7.8	14.1
3/7/2019	FOREST TOWER	1.07	0.01	0.02	0.003	0.48	8.0	12.2
3/7/2019	LAWLER TOWER	3.88	0.02	0.03	0.004	0.55	7.8	11.3
3/8/2019	3021 WAGON WHEEL	3.40	0.03	0.02	0.003	0.61	7.9	13.5
3/8/2019	FIREWHEEL PS	3.42	0.02	0.07	0.003	0.63	7.8	10.6
3/8/2019	498 CANTERBURY	3.04	0.02	0.07	0.002	0.61	7.9	12.3
3/8/2019	1902 PLEASANT VALLEY	2.76	0.00	0.03	0.003	0.56	7.9	13.5
3/8/2019	BROADWAY PS	3.18	0.00	0.01	0.003	0.56	7.9	11.3
3/8/2019	4301 BROADWAY	3.04	0.02	0.03	0.003	0.52	7.8	12.5
3/8/2019	5626 LYONS	1.87	0.00	0.01	0.003	0.46	7.9	13.5
3/8/2019	1538 E I30	1.65	0.01	0.04	0.004	0.51	7.9	14.0
3/8/2019	1426 COMMERCE	2.34	0.08	0.00	0.002	0.52	7.9	12.5
3/11/2019	APOLLO PS	3.59	0.01	0.00	0.002	0.42	8.2	12.1
3/11/2019	7602 N JUPITER	3.11	0.00	0.00	0.002	0.46	8.2	13.8
3/11/2019	1301 JUPITER	3.16	0.02	0.00	0.002	0.42	8.3	14.4
3/11/2019	2218 S JUPITER	2.99	0.01	0.08	0.001	0.42	8.2	14.6
3/11/2019	119 BUCKINGHAM	2.92	0.00	0.00	0.002	0.50	8.1	13.9
3/11/2019	WALLACE PS	3.32	0.00	0.04	0.003	0.50	8.3	12.2

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
3/11/2019	1980 FOREST	2.85	0.02	0.02	0.005	0.54	8.1	14.5
3/11/2019	FOREST TOWER	3.06	0.00	0.04	0.001	0.43	8.2	13.6
3/11/2019	LAWLER TOWER	3.43	0.01	0.00	0.002	0.45	8.3	12.3
3/12/2019	3021 WAGON WHEEL	3.15	0.00	0.00	0.002	0.49	8.1	14.3
3/12/2019	FIREWHEEL PS	3.50	0.00	0.00	0.003	0.56	8.1	13.3
3/12/2019	498 CANTERBURY	3.25	0.01	0.00	0.002	0.50	8.1	13.3
3/12/2019	1902 PLEASANT VALLEY	3.10	0.01	0.00	0.001	0.50	8.2	13.8
3/12/2019	LAVON PS	3.29	0.00	0.00	0.004	0.52	8.2	13.3
3/12/2019	BROADWAY PS	3.34	0.00	0.00	0.002	0.53	8.2	12.7
3/12/2019	4301 BROADWAY	3.21	0.02	0.05	0.002	0.46	8.2	13.1
3/12/2019	5626 LYONS	2.92	0.00	0.01	0.001	0.51	8.2	14.2
3/12/2019	1538 E I30	2.74	0.00	0.09	0.002	0.46	8.2	14.7
3/12/2019	1426 COMMERCE	3.12	0.01	0.00	0.002	0.50	8.2	13.3
3/12/2019	COMMERCE TOWER	3.12	0.00	0.01	0.001	0.47	8.2	13.2
3/19/2019	APOLLO PS	4.07	0.02	0.32	0.003	0.59	7.6	14.2
3/19/2019	7602 N JUPITER	3.60	0.02	0.00	0.003	0.48	7.7	15.0
3/19/2019	1301 JUPITER	3.45	0.01	0.03	0.003	0.50	7.7	16.7
3/19/2019	2218 S JUPITER	3.14	0.03	0.00	0.002	0.47	7.8	15.9
3/19/2019	5013 SATURN	3.13	0.04	0.05	0.002	0.50	7.9	14.9
3/19/2019	119 BUCKINGHAM	3.39	0.00	0.00	0.003	0.57	7.8	14.4
3/19/2019	WALLACE PS	3.70	0.03	0.13	0.002	0.52	7.8	14.7
3/19/2019	1980 FOREST	3.26	0.02	0.05	0.003	0.56	7.8	14.3
3/19/2019	FOREST TOWER	3.13	0.01	0.01	0.001	0.48	7.9	13.8
3/19/2019	LAWLER TOWER	4.00	0.03	0.17	0.002	0.56	7.7	13.8
3/20/2019	3021 WAGON WHEEL	3.50	0.04	0.00	0.002	0.57	7.9	15.5
3/20/2019	FIREWHEEL PS	3.67	0.01	0.00	0.001	0.60	7.9	14.2
3/20/2019	498 CANTERBURY	3.52	0.00	0.00	0.002	0.66	7.9	14.5
3/20/2019	1902 PLEASANT VALLEY	3.24	0.00	0.10	0.002	0.58	7.8	14.7
3/20/2019	LAVON PS	3.41	0.02	0.02	0.002	0.57	8.0	14.3
3/20/2019	BROADWAY PS	3.53	0.05	0.01	0.003	0.58	7.8	14.8
3/20/2019	4301 BROADWAY	3.38	0.01	0.00	0.002	0.59	7.8	14.7
3/20/2019	5626 LYONS	3.10	0.01	0.01	0.003	0.59	7.8	15.6
3/20/2019	1538 E I30	3.17	0.02	0.07	0.002	0.60	7.8	15.5

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
3/20/2019	1426 COMMERCE	3.18	0.02	0.01	0.002	0.54	7.9	14.5
3/20/2019	COMMERCE TOWER	3.26	0.02	0.00	0.002	0.53	7.9	14.5
3/26/2019	APOLLO PS	3.43	0.03	0.01	0.002	0.48	8.1	15.6
3/26/2019	7602 N JUPITER	3.10	0.02	0.00	0.002	0.51	8.1	17.2
3/26/2019	1301 JUPITER	2.23	0.02	0.06	0.001	0.45	7.9	18.5
3/26/2019	2218 S JUPITER	3.06	0.00	0.00	0.001	0.45	8.1	16.7
3/26/2019	5013 SATURN	3.03	0.01	0.00	0.001	0.41	8.1	14.8
3/26/2019	119 BUCKINGHAM	3.20	0.00	0.05	0.001	0.49	8.1	14.6
3/26/2019	WALLACE PS	3.27	0.00	0.01	0.002	0.41	7.9	13.8
3/26/2019	1980 FOREST	3.19	0.04	0.00	0.003	0.49	8.1	14.7
3/26/2019	FOREST TOWER	3.21	0.00	0.01	0.001	0.50	8.2	14.2
3/26/2019	LAWLER TOWER	3.18	0.01	0.01	0.001	0.46	8.0	16.8
3/27/2019	LAWLER TOWER	3.55	0.04	0.04	0.003	0.47	8.1	16.8
3/28/2019	3021 WAGON WHEEL	3.30	0.02	0.00	0.001	0.55	8.1	16.7
3/28/2019	FIREWHEEL PS	3.57	0.02	0.02	0.001	0.58	8.1	16.1
3/28/2019	498 CANTERBURY	3.13	0.03	0.11	0.003	0.60	8.0	17.4
3/28/2019	1902 PLEASANT VALLEY	2.93	0.01	0.12	0.002	0.57	7.8	16.5
3/28/2019	LAVON PS	3.08	0.04	0.01	0.003	0.58	7.9	15.4
3/28/2019	BROADWAY PS	3.06	0.00	0.03	0.004	0.57	7.9	15.3
3/28/2019	4301 BROADWAY	3.10	0.02	0.05	0.003	0.56	7.9	15.7
3/28/2019	5626 LYONS	2.96	0.04	0.21	0.002	0.60	7.7	15.8
3/28/2019	1538 E I30	2.87	0.01	0.03	0.002	0.60	7.8	17.6
3/28/2019	1426 COMMERCE	3.05	0.01	0.01	0.003	0.55	7.8	15.1
3/28/2019	COMMERCE TOWER	3.12	0.03	0.04	0.002	0.50	7.8	15.3
3/29/2019	APOLLO PS	3.59	0.02	0.12	0.002	0.58	8.1	16.6
3/29/2019	WALLACE PS	3.39	0.03	0.03	0.003	0.59	8.2	16.1
3/29/2019	FOREST TOWER	3.20	0.00	0.01	0.002	0.57	8.3	16.9
3/29/2019	LAWLER TOWER	3.37	0.01	0.02	0.002	0.59	8.1	16.7
3/29/2019	FIREWHEEL PS	3.42	0.02	0.01	0.004	0.60	8.2	16.9
3/29/2019	LAVON PS	3.29	0.02	0.02	0.001	0.59	8.2	16.2
3/29/2019	BROADWAY PS	3.11	0.01	0.00	0.002	0.60	8.3	16.1
3/29/2019	COMMERCE TOWER	3.20	0.02	0.01	0.002	0.55	8.1	16.1
4/1/2019	APOLLO PS	3.79	0.00	0.18	0.001	0.53	7.8	19.3

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
4/1/2019	7602 N JUPITER	3.47	0.00	0.03	0.001	0.47	8.0	21.2
4/1/2019	1301 JUPITER	3.12	0.00	0.01	0.001	0.58	7.9	23.0
4/1/2019	2218 S JUPITER	3.12	0.01	0.01	0.003	0.45	8.0	20.4
4/1/2019	5013 SATURN	2.58	0.05	0.00	0.003	0.37	8.0	20.1
4/1/2019	119 BUCKINGHAM	3.38	0.01	0.02	0.001	0.49	8.3	17.4
4/1/2019	WALLACE PS	3.39	0.03	0.00	0.003	0.59	8.2	19.8
4/1/2019	1980 FOREST	3.00	0.01	0.00	0.001	0.41	8.5	17.3
4/1/2019	FOREST TOWER	3.12	0.04	0.02	0.002	0.57	8.5	17.2
4/1/2019	LAWLER TOWER	3.02	0.04	0.00	0.002	0.46	8.1	21.1
4/2/2019	3021 WAGON WHEEL	1.57	0.15	0.00	0.001	0.60	8.1	17.2
4/2/2019	FIREWHEEL PS	1.01	0.56	0.00	0.002	0.49	7.7	19.6
4/2/2019	498 CANTERBURY	1.58	0.16	0.09	0.003	0.46	7.0	19.0
4/2/2019	1902 PLEASANT VALLEY	2.86	0.01	0.00	0.002	0.50	7.2	21.6
4/2/2019	LAVON PS	0.40	0.05	0.01	0.002	0.68	7.0	20.8
4/2/2019	BROADWAY PS	0.35	0.09	0.01	0.002	0.59	7.2	20.5
4/2/2019	4301 BROADWAY	0.86	0.00	0.01	0.003	0.49	7.0	22.0
4/2/2019	5626 LYONS	2.62	0.02	0.00	0.001	0.62	7.2	23.8
4/2/2019	1538 E I30	2.68	0.02	0.00	0.003	0.58	7.3	23.8
4/2/2019	1426 COMMERCE	2.47	0.04	0.03	0.003	0.38	7.3	19.7
4/2/2019	COMMERCE TOWER	1.57	0.02	0.10	0.002	0.65	7.1	21.0
4/5/2019	APOLLO PS	3.74	3.45	0.12	0.007	0.55	8.0	16.8
4/5/2019	WALLACE PS	3.53	3.46	0.14	0.007	0.56	8.2	16.9
4/5/2019	FOREST TOWER	3.45	3.41	0.10	0.008	0.60	8.2	17.3
4/5/2019	LAWLER TOWER	3.73	3.49	0.12	0.006	0.44	8.2	16.0
4/5/2019	FIREWHEEL PS	3.49	3.36	0.15	0.005	0.51	8.1	17.1
4/5/2019	LAVON PS	2.84	2.75	0.12	0.007	0.68	8.2	17.3
4/5/2019	BROADWAY PS	2.84	2.75	0.12	0.007	0.68	8.2	17.3
4/5/2019	COMMERCE TOWER	2.84	2.75	0.12	0.007	0.68	8.2	17.3
4/8/2019	APOLLO PS	3.51	3.27	0.05	0.006	0.46	8.1	15.7
4/8/2019	7602 N JUPITER	3.53	3.47	0.11	0.009	0.44	8.3	15.8
4/8/2019	1301 JUPITER	3.16	3.06	0.19	0.007	0.40	8.1	16.2
4/8/2019	2218 S JUPITER	3.27	3.21	0.12	0.009	0.48	8.1	18.6
4/8/2019	5013 SATURN	3.24	3.16	0.14	0.008	0.47	8.2	17.7

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
4/8/2019	119 BUCKINGHAM	3.28	3.19	0.08	0.007	0.43	8.1	16.7
4/8/2019	WALLACE PS	3.39	3.28	0.08	0.008	0.53	8.1	16.6
4/8/2019	1980 FOREST	3.39	3.32	0.25	0.007	0.45	8.1	17.3
4/8/2019	FOREST TOWER	3.25	3.18	0.07	0.006	0.43	8.1	17.2
4/8/2019	LAWLER TOWER	3.30	3.22	0.16	0.006	0.40	8.1	16.6
4/9/2019	3021 WAGON WHEEL	3.43	3.22	0.09	0.005	0.46	8.1	17.1
4/9/2019	FIREWHEEL PS	3.39	3.33	0.10	0.006	0.45	8.2	16.0
4/9/2019	498 CANTERBURY	3.38	3.26	0.12	0.006	0.44	8.2	16.3
4/9/2019	1902 PLEASANT VALLEY	3.15	2.99	0.18	0.006	0.43	8.2	17.0
4/9/2019	LAVON PS	3.38	3.35	0.11	0.005	0.40	8.3	16.8
4/9/2019	BROADWAY PS	3.29	3.27	0.11	0.005	0.45	8.2	16.7
4/9/2019	4301 BROADWAY	3.16	3.09	0.27	0.004	0.43	8.1	16.6
4/9/2019	5626 LYONS	3.08	3.04	0.13	0.006	0.46	8.1	16.9
4/9/2019	1538 E I30	3.16	3.07	0.13	0.006	0.50	8.2	17.2
4/9/2019	1426 COMMERCE	3.12	3.08	0.15	0.006	0.43	8.2	16.4
4/9/2019	COMMERCE TOWER	3.19	3.10	0.24	0.007	0.57	8.2	16.9
4/12/2019	APOLLO PS	3.55	3.45	0.11	0.006	0.52	8.0	18.9
4/12/2019	WALLACE PS	3.44	3.17	0.12	0.005	0.53	8.1	17.0
4/12/2019	FOREST TOWER	3.40	3.16	0.09	0.005	0.65	8.0	17.3
4/12/2019	LAWLER TOWER	3.19	3.04	0.14	0.005	0.58	8.0	18.3
4/12/2019	FIREWHEEL PS	3.20	3.08	0.15	0.004	0.52	7.9	18.1
4/12/2019	LAVON PS	3.23	3.12	0.15	0.006	0.57	8.2	17.6
4/12/2019	BROADWAY PS	3.25	3.03	0.13	0.004	0.54	8.0	17.5
4/12/2019	COMMERCE TOWER	3.12	3.06	0.18	0.006	0.53	8.2	17.5
4/15/2019	APOLLO PS	3.47	3.19	0.15	0.003	0.50	7.7	17.0
4/15/2019	7602 N JUPITER	3.10	3.06	0.15	0.005	0.47	7.9	18.5
4/15/2019	1301 JUPITER	3.18	2.91	0.19	0.004	0.48	7.9	18.2
4/15/2019	2218 S JUPITER	3.01	2.90	0.17	0.004	0.50	7.9	19.2
4/15/2019	5013 SATURN	2.90	2.78	0.20	0.004	0.51	8.0	18.6
4/15/2019	119 BUCKINGHAM	2.84	2.77	0.16	0.004	0.46	8.0	18.7
4/15/2019	WALLACE PS	3.11	2.98	0.16	0.004	0.55	8.0	18.6
4/15/2019	1980 FOREST	3.10	2.96	0.16	0.003	0.47	7.9	18.2
4/15/2019	FOREST TOWER	2.93	2.76	0.18	0.004	0.57	7.9	18.5

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
4/15/2019	LAWLER TOWER	3.21	2.99	0.16	0.004	0.56	8.0	16.7
4/17/2019	3021 WAGON WHEEL	3.31	3.19	0.18	0.003	0.51	7.9	19.1
4/17/2019	FIREWHEEL PS	2.89	2.68	0.22	0.003	0.53	7.7	18.1
4/17/2019	498 CANTERBURY	2.89	2.54	0.29	0.003	0.51	7.7	18.2
4/17/2019	1902 PLEASANT VALLEY	2.77	2.74	0.15	0.003	0.47	7.8	19.0
4/17/2019	LAVON PS	3.21	3.11	0.21	0.003	0.55	8.0	18.9
4/17/2019	BROADWAY PS	3.00	2.92	0.18	0.002	0.56	7.8	17.8
4/17/2019	4301 BROADWAY	2.99	2.88	0.21	0.003	0.48	7.8	18.2
4/17/2019	5626 LYONS	2.78	2.72	0.24	0.004	0.50	7.9	18.6
4/17/2019	1538 E I30	2.83	2.73	0.18	0.003	0.55	7.9	18.4
4/17/2019	1426 COMMERCE	3.04	3.03	0.21	0.004	0.53	8.0	18.2
4/17/2019	COMMERCE TOWER	3.09	3.03	0.15	0.003	0.55	8.0	18.2
4/19/2019	APOLLO PS	3.50	3.44	0.33	0.009	0.43	8.5	17.0
4/19/2019	WALLACE PS	3.40	3.30	0.17	0.008	0.37	8.4	16.5
4/19/2019	FOREST TOWER	3.22	3.19	0.10	0.009	0.42	8.3	18.1
4/19/2019	LAWLER TOWER	3.17	3.12	0.16	0.006	0.44	8.2	17.1
4/19/2019	FIREWHEEL PS	3.14	3.09	0.22	0.007	0.45	8.2	17.5
4/19/2019	LAVON PS	3.08	3.00	0.20	0.004	0.47	8.0	17.4
4/19/2019	BROADWAY PS	3.25	3.28	0.15	0.005	0.42	8.2	16.9
4/19/2019	COMMERCE TOWER	3.02	2.96	0.18	0.004	0.45	7.9	17.7
4/23/2019	3021 WAGON WHEEL	3.49	3.45	0.16	0.007	0.46	8.2	19.4
4/23/2019	FIREWHEEL PS	3.30	3.26	0.21	0.005	0.50	8.2	19.0
4/23/2019	498 CANTERBURY	3.27	3.22	0.16	0.005	0.46	8.2	18.7
4/23/2019	1902 PLEASANT VALLEY	3.24	3.19	0.16	0.006	0.50	8.2	19.7
4/23/2019	BROADWAY PS	3.15	3.03	0.18	0.006	0.43	8.2	19.6
4/23/2019	4301 BROADWAY	3.23	3.20	0.16	0.006	0.65	8.1	19.4
4/23/2019	5626 LYONS	3.12	3.06	0.17	0.006	0.54	8.2	20.2
4/23/2019	1538 E I30	3.16	3.14	0.15	0.005	0.43	8.2	19.7
4/23/2019	1426 COMMERCE	3.26	3.24	0.16	0.004	0.44	8.2	19.6
4/23/2019	COMMERCE TOWER	3.24	3.26	0.15	0.005	0.49	8.2	19.9
4/24/2019	APOLLO PS	3.49	3.42	0.11	0.004	0.43	8.0	17.7
4/24/2019	7602 N JUPITER	3.43	3.43	0.15	0.007	0.45	8.2	18.3
4/24/2019	1301 JUPITER	3.22	3.09	0.21	0.008	0.48	8.0	19.8

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
4/24/2019	2218 S JUPITER	3.24	3.22	0.18	0.009	0.45	8.1	19.9
4/24/2019	5013 SATURN	3.32	3.29	0.14	0.007	0.44	8.2	17.9
4/24/2019	119 BUCKINGHAM	3.31	3.25	0.16	0.007	0.45	8.2	18.2
4/24/2019	WALLACE PS	3.37	3.36	0.15	0.007	0.48	8.2	17.4
4/24/2019	1980 FOREST	3.42	3.31	0.15	0.007	0.48	8.2	17.7
4/24/2019	FOREST TOWER	3.45	3.35	0.14	0.007	0.50	8.2	18.0
4/24/2019	LAWLER TOWER	3.39	3.31	0.17	0.008	0.42	8.2	18.6
4/24/2019	LAVON PS	3.45	3.33	0.15	0.007	0.60	8.2	17.4
4/29/2019	APOLLO PS	3.49	3.41	0.07	0.006	0.47	8.2	20.1
4/29/2019	7602 N JUPITER	3.41	3.34	0.12	0.008	0.50	8.2	20.8
4/29/2019	1301 JUPITER	3.19	3.16	0.09	0.007	0.44	8.2	22.0
4/29/2019	2218 S JUPITER	3.30	3.23	0.14	0.009	0.47	8.2	21.2
4/29/2019	5013 SATURN	3.38	3.32	0.11	0.008	0.48	8.3	20.2
4/29/2019	119 BUCKINGHAM	3.24	3.25	0.11	0.007	0.48	8.2	20.4
4/29/2019	WALLACE PS	3.45	3.36	0.09	0.007	0.55	8.3	19.8
4/29/2019	1980 FOREST	3.43	3.46	0.10	0.008	0.54	8.2	19.8
4/29/2019	FOREST TOWER	3.40	3.36	0.11	0.009	0.49	8.2	20.1
4/29/2019	LAWLER TOWER	3.49	3.05	0.15	0.007	0.45	8.2	20.3
4/30/2019	3021 WAGON WHEEL	3.44	3.38	0.10	0.008	0.49	8.2	20.4
4/30/2019	FIREWHEEL PS	3.46	3.37	0.12	0.006	0.42	8.2	20.4
4/30/2019	498 CANTERBURY	3.30	3.25	0.12	0.006	0.51	8.2	20.0
4/30/2019	1902 PLEASANT VALLEY	3.18	3.13	0.13	0.006	0.51	8.2	20.2
4/30/2019	LAVON PS	3.34	3.27	0.11	0.007	0.48	8.3	20.3
4/30/2019	BROADWAY PS	3.27	3.23	0.13	0.007	0.50	8.2	20.6
4/30/2019	4301 BROADWAY	3.22	3.15	0.14	0.006	0.50	8.2	20.7
4/30/2019	5626 LYONS	3.19	3.14	0.15	0.007	0.47	8.3	20.4
4/30/2019	1538 E I30	3.19	3.14	0.15	0.008	0.50	8.2	20.2
4/30/2019	1426 COMMERCE	3.22	3.16	0.15	0.006	0.44	8.3	20.7
4/30/2019	COMMERCE TOWER	3.25	3.19	0.18	0.006	0.51	8.3	20.5
5/3/2019	FIREWHEEL PS	3.29	3.27	0.11	0.009	0.52	8.0	22.7
5/3/2019	LAVON PS	3.26	3.14	0.11	0.008	0.52	8.2	23.5
5/3/2019	BROADWAY PS	3.32	3.30	0.11	0.008	0.48	8.1	23.2
5/3/2019	COMMERCE TOWER	3.26	3.25	0.11	0.008	0.53	8.2	22.9

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
5/6/2019	APOLLO PS	3.56	3.49	0.20	0.008	0.42	8.1	20.4
5/6/2019	7602 N JUPITER	3.50	3.54	0.16	0.009	0.46	8.2	20.4
5/6/2019	1301 JUPITER	3.24	3.17	0.27	0.008	0.42	8.1	21.8
5/6/2019	2218 S JUPITER	3.39	3.41	0.18	0.009	0.45	8.2	20.4
5/6/2019	5013 SATURN	3.38	3.30	0.15	0.009	0.42	8.3	19.9
5/6/2019	119 BUCKINGHAM	3.22	3.16	0.15	0.010	0.39	8.3	19.9
5/6/2019	WALLACE PS	3.58	3.60	0.17	0.100	0.46	8.2	20.1
5/6/2019	1980 FOREST	3.62	3.60	0.15	0.009	0.47	8.3	19.6
5/6/2019	FOREST TOWER	3.61	3.56	0.16	0.009	0.44	8.3	21.6
5/6/2019	LAWLER TOWER	3.47	3.39	0.33	0.008	0.49	8.3	20.9
5/7/2019	3021 WAGON WHEEL	3.43	3.42	0.20	0.008	0.49	8.2	21.3
5/7/2019	FIREWHEEL PS	3.42	3.44	0.24	0.007	0.41	8.2	21.7
5/7/2019	498 CANTERBURY	3.34	3.32	0.19	0.006	0.46	8.2	21.2
5/7/2019	1902 PLEASANT VALLEY	3.18	3.13	0.18	0.008	0.37	8.2	21.1
5/7/2019	LAVON PS	3.41	3.38	0.20	0.008	0.42	8.2	22.0
5/7/2019	BROADWAY PS	3.36	3.38	0.18	0.008	0.46	8.2	21.9
5/7/2019	4301 BROADWAY	3.34	3.31	0.20	0.007	0.46	8.2	21.8
5/7/2019	5626 LYONS	3.30	3.28	0.18	0.008	0.41	8.3	21.2
5/7/2019	1538 E I30	3.27	3.24	0.19	0.010	0.44	8.2	21.1
5/7/2019	1426 COMMERCE	3.30	3.30	0.18	0.007	0.42	8.2	21.4
5/7/2019	COMMERCE TOWER	3.34	3.24	0.19	0.007	0.43	8.2	21.6
5/10/2019	APOLLO PS	3.61	3.52	0.12	0.009	0.69	8.4	18.9
5/10/2019	WALLACE PS	3.44	3.30	0.17	0.009	0.52	8.2	19.1
5/10/2019	FOREST TOWER	2.97	2.83	0.23	0.010	0.43	8.3	17.8
5/10/2019	LAWLER TOWER	3.32	3.29	0.17	0.009	0.57	8.3	18.5
5/10/2019	FIREWHEEL PS	3.33	3.27	0.20	0.008	0.57	8.3	18.5
5/10/2019	LAVON PS	3.30	3.22	0.20	0.009	0.48	8.3	19.4
5/10/2019	BROADWAY PS	3.27	3.17	0.20	0.009	0.68	8.3	18.7
5/10/2019	COMMERCE TOWER	3.27	3.19	0.21	0.009	0.71	8.3	19.0
5/11/2019	7602 N JUPITER	3.47	3.37	0.10	0.008	0.57	8.3	19.3
5/11/2019	1301 JUPITER	3.05	3.02	0.15	0.009	0.49	8.2	18.5
5/11/2019	2218 S JUPITER	3.39	3.38	0.10	0.010	0.47	8.4	18.2
5/11/2019	5013 SATURN	3.38	3.29	0.11	0.008	0.48	8.1	23.9

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
5/11/2019	119 BUCKINGHAM	3.11	3.06	0.16	0.010	0.53	8.2	22.9
5/11/2019	1980 FOREST	3.32	3.28	0.28	0.011	0.52	8.2	24.3
5/11/2019	3021 WAGON WHEEL	3.42	3.36	0.09	0.010	0.55	8.4	20.5
5/11/2019	498 CANTERBURY	3.33	3.26	0.13	0.008	0.82	8.2	19.9
5/11/2019	1902 PLEASANT VALLEY	3.12	3.02	0.21	0.009	0.67	8.1	22.2
5/11/2019	4301 BROADWAY	3.31	3.28	0.14	0.009	0.68	8.2	24.1
5/11/2019	5626 LYONS	3.16	3.14	0.16	0.009	0.63	8.2	23.9
5/11/2019	1538 E I30	3.12	3.16	0.16	0.009	0.49	8.1	23.3
5/11/2019	1426 COMMERCE	3.18	3.11	0.19	0.009	0.50	8.2	23.7
5/12/2019	APOLLO PS	3.26	3.24	0.05	0.009	0.60	0.0	0.0
5/12/2019	7602 N JUPITER	3.22	3.15	0.08	0.008	0.50	8.3	20.7
5/12/2019	1301 JUPITER	3.06	3.05	0.06	0.007	0.44	8.2	21.4
5/12/2019	2218 S JUPITER	3.00	2.94	0.14	0.010	0.38	8.3	19.6
5/12/2019	5013 SATURN	3.28	3.23	0.11	0.009	0.41	8.3	19.7
5/12/2019	119 BUCKINGHAM	3.21	3.21	0.11	0.009	0.44	8.3	18.9
5/12/2019	WALLACE PS	3.23	3.23	0.31	0.007	0.61	0.0	0.0
5/12/2019	1980 FOREST	3.28	3.30	0.08	0.009	0.54	8.3	19.8
5/12/2019	FOREST TOWER	3.09	3.03	0.22	0.009	0.44	0.0	0.0
5/12/2019	LAWLER TOWER	3.26	3.28	0.12	0.007	0.56	0.0	0.0
5/12/2019	3021 WAGON WHEEL	3.26	3.30	0.09	0.009	0.48	8.3	19.0
5/12/2019	FIREWHEEL PS	3.29	3.35	0.14	0.007	0.54	0.0	0.0
5/12/2019	498 CANTERBURY	3.26	3.20	0.12	0.007	0.42	8.2	18.6
5/12/2019	1902 PLEASANT VALLEY	3.14	3.08	0.17	0.007	0.44	8.2	18.7
5/12/2019	LAVON PS	3.22	3.19	0.07	0.009	0.62	0.0	0.0
5/12/2019	BROADWAY PS	3.21	3.22	0.12	0.007	0.73	0.0	0.0
5/12/2019	4301 BROADWAY	3.21	3.17	0.13	0.008	0.51	8.3	19.9
5/12/2019	5626 LYONS	3.18	3.13	0.15	0.007	0.40	8.3	19.2
5/12/2019	1538 E I30	3.19	3.05	0.13	0.009	0.40	8.3	19.4
5/12/2019	1426 COMMERCE	3.17	3.19	0.15	0.009	0.41	8.3	18.8
5/12/2019	COMMERCE TOWER	3.16	3.14	0.00	0.008	0.54	0.0	0.0
5/14/2019	APOLLO PS	3.65	3.60	0.06	0.007	0.51	8.1	20.2
5/14/2019	7602 N JUPITER	3.52	3.47	0.11	0.010	0.47	8.4	20.5
5/14/2019	1301 JUPITER	3.36	3.32	0.14	0.008	0.51	8.2	21.5

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
5/14/2019	2218 S JUPITER	3.25	3.21	0.12	0.009	0.49	8.2	20.8
5/14/2019	5013 SATURN	3.30	3.23	0.12	0.008	0.45	8.2	19.9
5/14/2019	119 BUCKINGHAM	3.46	3.42	0.11	0.009	0.55	8.3	19.7
5/14/2019	WALLACE PS	3.63	3.60	0.10	0.009	0.47	8.4	19.6
5/14/2019	1980 FOREST	3.40	3.29	0.12	0.008	0.56	8.3	19.7
5/14/2019	FOREST TOWER	3.41	3.34	0.12	0.008	0.47	8.3	19.6
5/14/2019	LAWLER TOWER	3.61	3.57	0.10	0.008	0.50	8.2	20.6
5/15/2019	3021 WAGON WHEEL	3.35	3.35	0.11	0.005	0.40	8.0	21.8
5/15/2019	FIREWHEEL PS	3.38	3.41	0.13	0.006	0.49	8.2	21.9
5/15/2019	498 CANTERBURY	3.27	3.23	0.12	0.006	0.45	8.2	21.5
5/15/2019	1902 PLEASANT VALLEY	3.33	3.30	0.13	0.007	0.50	8.2	22.0
5/15/2019	LAVON PS	3.41	3.38	0.10	0.006	0.46	8.1	22.0
5/15/2019	BROADWAY PS	3.29	3.22	0.12	0.006	0.50	8.2	23.8
5/15/2019	4301 BROADWAY	3.31	3.27	0.11	0.006	0.53	8.2	22.5
5/15/2019	5626 LYONS	3.26	3.21	0.13	0.008	0.54	8.3	22.0
5/15/2019	1538 E I30	3.24	3.16	0.15	0.008	0.51	8.3	21.9
5/15/2019	1426 COMMERCE	3.26	3.20	0.12	0.006	0.48	8.2	22.3
5/15/2019	COMMERCE TOWER	3.29	3.30	0.13	0.006	0.41	8.2	22.3
5/16/2019	APOLLO PS	3.58	3.55	0.10	0.008	0.48	8.2	22.0
5/16/2019	WALLACE PS	3.58	3.52	0.19	0.009	0.48	8.3	21.8
5/16/2019	FOREST TOWER	3.41	3.32	0.20	0.008	0.43	8.3	21.9
5/16/2019	LAWLER TOWER	3.55	3.56	0.20	0.008	0.48	8.3	21.8
5/16/2019	FIREWHEEL PS	3.26	3.23	0.15	0.006	0.45	8.2	21.9
5/16/2019	LAVON PS	3.52	3.41	0.21	0.009	0.45	8.3	21.9
5/16/2019	BROADWAY PS	3.35	3.32	0.16	0.009	0.47	8.3	22.3
5/16/2019	COMMERCE TOWER	3.46	3.41	0.24	0.009	0.41	8.2	22.1
5/20/2019	APOLLO PS	3.44	3.39	0.18	0.006	0.48	7.8	21.1
5/20/2019	7602 N JUPITER	3.58	3.52	0.24	0.006	0.54	8.0	21.2
5/20/2019	1301 JUPITER	3.06	2.97	0.26	0.007	0.45	7.8	22.1
5/20/2019	2218 S JUPITER	3.29	3.33	0.25	0.008	0.54	8.1	21.8
5/20/2019	5013 SATURN	3.32	3.30	0.16	0.007	0.51	8.1	21.3
5/20/2019	119 BUCKINGHAM	3.50	3.49	0.22	0.007	0.49	8.1	20.5
5/20/2019	WALLACE PS	3.53	3.51	0.22	0.005	0.48	8.0	21.1

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
5/20/2019	1980 FOREST	3.54	3.45	0.19	0.006	0.52	8.0	20.1
5/20/2019	FOREST TOWER	3.56	3.53	0.25	0.006	0.61	8.0	20.6
5/20/2019	LAWLER TOWER	3.43	3.37	0.17	0.004	0.51	7.9	21.1
5/21/2019	3021 WAGON WHEEL	3.28	3.26	0.17	0.005	0.47	8.0	22.4
5/21/2019	FIREWHEEL PS	3.45	3.34	0.14	0.005	0.47	8.0	22.8
5/21/2019	498 CANTERBURY	3.33	3.31	0.15	0.004	0.42	8.0	22.2
5/21/2019	1902 PLEASANT VALLEY	3.20	3.19	0.22	0.006	0.47	8.1	22.0
5/21/2019	LAVON PS	3.33	3.27	0.14	0.004	0.46	8.1	22.8
5/21/2019	BROADWAY PS	3.25	3.19	0.16	0.004	0.46	7.9	23.3
5/21/2019	4301 BROADWAY	3.31	3.30	0.13	0.004	0.44	8.0	22.9
5/21/2019	5626 LYONS	3.20	3.19	0.21	0.005	0.42	8.1	22.3
5/21/2019	1538 E I30	3.16	3.09	0.23	0.006	0.47	8.0	22.4
5/21/2019	1426 COMMERCE	2.93	2.86	0.20	0.034	0.49	8.0	22.9
5/21/2019	COMMERCE TOWER	3.26	3.26	0.19	0.004	0.47	8.0	22.8
5/24/2019	APOLLO PS	3.51	3.47	0.22	0.010	0.49	8.4	22.6
5/24/2019	WALLACE PS	3.40	3.39	0.22	0.010	0.50	8.3	23.6
5/24/2019	FOREST TOWER	3.32	3.32	0.22	0.010	0.48	8.3	22.1
5/24/2019	LAWLER TOWER	3.50	3.47	0.20	0.010	0.50	8.4	22.6
5/24/2019	FIREWHEEL PS	3.21	3.19	0.15	0.006	0.47	8.1	22.3
5/24/2019	LAVON PS	3.33	3.27	0.17	0.009	0.42	8.3	21.0
5/24/2019	BROADWAY PS	3.15	3.17	0.15	0.007	0.41	8.2	21.4
5/24/2019	COMMERCE TOWER	3.36	3.29	0.16	0.009	0.44	8.3	21.1
5/29/2019	APOLLO PS	3.62	3.64	0.13	0.009	0.35	8.2	22.6
5/29/2019	7602 N JUPITER	3.31	3.30	0.19	0.006	0.37	8.0	22.5
5/29/2019	1301 JUPITER	3.08	3.02	0.25	0.008	0.34	8.0	23.0
5/29/2019	2218 S JUPITER	3.13	3.05	0.21	0.009	0.29	8.0	22.9
5/29/2019	5013 SATURN	3.16	3.13	0.17	0.007	0.45	8.1	23.9
5/29/2019	119 BUCKINGHAM	3.22	3.20	0.21	0.006	0.37	8.0	22.3
5/29/2019	WALLACE PS	3.48	3.48	0.15	0.007	0.44	8.1	22.5
5/29/2019	1980 FOREST	3.30	3.26	0.19	0.008	0.41	8.1	22.2
5/29/2019	FOREST TOWER	3.32	3.38	0.19	0.007	0.39	8.1	21.6
5/29/2019	LAWLER TOWER	3.30	3.27	0.17	0.006	0.36	8.1	23.0
5/30/2019	3021 WAGON WHEEL	3.50	3.47	0.21	0.009	0.37	8.3	21.1

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
5/30/2019	FIREWHEEL PS	3.37	3.38	0.18	0.006	0.36	8.1	22.4
5/30/2019	498 CANTERBURY	3.31	3.20	0.22	0.006	0.43	8.1	21.8
5/30/2019	1902 PLEASANT VALLEY	2.92	2.91	0.24	0.008	0.43	8.0	21.4
5/30/2019	LAVON PS	3.33	3.24	0.19	0.006	0.35	8.1	22.1
5/30/2019	BROADWAY PS	3.46	3.45	0.18	0.008	0.38	8.3	22.1
5/30/2019	4301 BROADWAY	3.41	3.36	0.21	0.009	0.40	8.3	22.3
5/30/2019	5626 LYONS	3.04	2.95	0.27	0.008	0.36	8.1	21.8
5/30/2019	1538 E I30	2.90	2.84	0.26	0.009	0.44	8.1	21.7
5/30/2019	1426 COMMERCE	3.24	3.17	0.20	0.006	0.36	8.1	21.9
5/30/2019	COMMERCE TOWER	3.30	3.24	0.20	0.007	0.36	8.1	22.0
5/31/2019	APOLLO PS	3.51	3.49	0.13	0.010	0.33	8.3	23.6
5/31/2019	WALLACE PS	3.43	3.42	0.19	0.008	0.47	8.2	22.4
5/31/2019	FOREST TOWER	3.35	3.36	0.20	0.010	0.42	8.3	22.5
5/31/2019	LAWLER TOWER	3.50	3.47	0.19	0.009	0.36	8.3	23.1
5/31/2019	FIREWHEEL PS	3.38	3.36	0.20	0.008	0.34	8.2	23.4
5/31/2019	LAVON PS	3.45	3.38	0.17	0.009	0.38	8.2	23.9
5/31/2019	BROADWAY PS	3.35	3.36	0.22	0.008	0.37	8.3	21.7
5/31/2019	COMMERCE TOWER	3.45	3.37	0.22	0.008	0.40	8.2	22.9
6/4/2019	APOLLO PS	3.63	3.49	0.18	0.009	0.37	7.9	28.7
6/4/2019	7602 N JUPITER	2.96	2.88	0.29	0.007	0.44	7.9	27.4
6/4/2019	1301 JUPITER	3.03	3.04	0.26	0.007	0.43	7.9	25.2
6/4/2019	2218 S JUPITER	3.00	2.88	0.23	0.005	0.40	8.1	24.3
6/4/2019	5013 SATURN	3.01	2.93	0.29	0.008	0.41	8.0	28.8
6/4/2019	119 BUCKINGHAM	3.03	2.92	0.26	0.007	0.39	8.1	28.6
6/4/2019	WALLACE PS	3.33	3.35	0.21	0.006	0.35	8.0	28.6
6/4/2019	1980 FOREST	2.96	2.85	0.33	0.006	0.36	7.9	28.1
6/4/2019	FOREST TOWER	2.91	2.83	0.28	0.007	0.34	7.9	28.4
6/4/2019	LAWLER TOWER	3.11	2.67	0.32	0.006	0.39	8.1	29.8
6/5/2019	3021 WAGON WHEEL	3.17	3.12	0.27	0.008	0.43	8.2	25.1
6/5/2019	FIREWHEEL PS	3.07	2.96	0.22	0.005	0.33	8.0	26.6
6/5/2019	498 CANTERBURY	2.99	2.91	0.23	0.006	0.35	8.0	25.3
6/5/2019	1902 PLEASANT VALLEY	3.03	3.00	0.28	0.008	0.31	8.2	25.9
6/5/2019	LAVON PS	3.52	3.44	0.24	0.007	0.43	8.2	22.8

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
6/5/2019	BROADWAY PS	3.40	3.39	0.24	0.008	0.39	8.0	25.7
6/5/2019	4301 BROADWAY	3.22	3.21	0.26	0.007	0.40	8.1	23.6
6/5/2019	5626 LYONS	2.77	2.71	0.31	0.007	0.34	8.1	22.1
6/5/2019	1538 E I30	2.61	2.56	0.37	0.008	0.42	8.1	20.9
6/5/2019	1426 COMMERCE	3.41	3.22	0.27	0.009	0.35	8.3	20.6
6/5/2019	COMMERCE TOWER	3.58	3.27	0.26	0.008	0.35	8.2	20.6
6/7/2019	APOLLO PS	3.53	3.45	0.18	0.008	0.41	8.0	25.8
6/7/2019	WALLACE PS	3.52	3.50	0.17	0.009	0.38	8.2	23.3
6/7/2019	FOREST TOWER	3.02	2.95	0.29	0.019	0.34	8.2	24.2
6/7/2019	LAWLER TOWER	3.25	3.11	0.24	0.008	0.33	8.1	25.2
6/7/2019	FIREWHEEL PS	3.17	3.12	0.20	0.007	0.37	8.0	26.5
6/7/2019	LAVON PS	3.55	3.49	0.18	0.006	0.36	8.0	26.7
6/7/2019	BROADWAY PS	3.26	3.24	0.21	0.007	0.40	8.1	23.5
6/7/2019	COMMERCE TOWER	3.50	3.48	0.18	0.009	0.27	8.1	24.3
6/11/2019	APOLLO PS	3.53	3.51	0.11	0.010	0.37	8.2	23.7
6/11/2019	7602 N JUPITER	3.27	3.19	0.17	0.011	0.31	8.3	23.5
6/11/2019	1301 JUPITER	3.10	3.18	0.18	0.011	0.34	8.3	23.0
6/11/2019	2218 S JUPITER	2.90	2.86	0.27	0.013	0.32	8.3	22.3
6/11/2019	5013 SATURN	2.91	2.85	0.23	0.011	0.31	8.1	22.6
6/11/2019	119 BUCKINGHAM	2.90	2.88	0.23	0.010	0.30	8.2	22.4
6/11/2019	WALLACE PS	2.49	2.47	0.12	0.009	0.33	8.3	22.5
6/11/2019	1980 FOREST	2.85	2.75	0.26	0.011	0.29	8.3	22.3
6/11/2019	FOREST TOWER	2.94	2.91	0.20	0.013	0.33	8.3	21.8
6/11/2019	LAWLER TOWER	3.35	3.31	0.15	0.010	0.33	8.3	23.2
6/13/2019	3021 WAGON WHEEL	3.10	3.09	0.28	0.011	0.30	8.3	21.6
6/13/2019	FIREWHEEL PS	3.36	3.36	0.16	0.010	0.25	8.3	22.8
6/13/2019	498 CANTERBURY	3.05	3.02	0.22	0.010	0.32	8.3	22.5
6/13/2019	1902 PLEASANT VALLEY	3.21	3.14	0.22	0.011	0.28	8.3	22.7
6/13/2019	LAVON PS	3.46	3.36	0.19	0.010	0.29	8.3	23.1
6/13/2019	BROADWAY PS	3.34	3.30	0.17	0.011	0.31	8.3	23.7
6/13/2019	4301 BROADWAY	3.20	3.18	0.23	0.011	0.31	8.3	23.5
6/13/2019	5626 LYONS	3.68	3.26	0.43	0.014	0.33	8.3	23.9
6/13/2019	1538 E I30	2.59	2.57	0.31	0.016	0.35	8.3	23.6

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
6/13/2019	1426 COMMERCE	3.38	3.42	0.17	0.010	0.29	8.3	23.3
6/13/2019	COMMERCE TOWER	3.49	3.49	0.16	0.010	0.31	8.3	23.4
6/14/2019	APOLLO PS	3.12	3.01	0.10	0.005	0.30	7.9	28.1
6/14/2019	WALLACE PS	3.11	3.10	0.15	0.007	0.34	8.1	27.5
6/14/2019	FOREST TOWER	2.66	2.60	0.21	0.006	0.28	8.1	25.2
6/14/2019	LAWLER TOWER	2.90	2.85	0.18	0.007	0.32	8.1	27.8
6/14/2019	FIREWHEEL PS	3.09	3.06	0.12	0.006	0.32	8.1	29.9
6/14/2019	LAVON PS	3.15	3.10	0.19	0.006	0.29	8.1	29.3
6/14/2019	BROADWAY PS	3.15	3.09	0.17	0.008	0.32	8.1	28.0
6/14/2019	COMMERCE TOWER	3.10	3.04	0.20	0.006	0.34	8.1	27.8
6/17/2019	APOLLO PS	3.18	3.19	0.15	0.007	0.29	8.1	26.4
6/17/2019	7602 N JUPITER	2.73	2.62	0.26	0.005	0.29	8.1	26.3
6/17/2019	1301 JUPITER	2.91	2.89	0.24	0.007	0.25	8.1	26.3
6/17/2019	2218 S JUPITER	2.40	2.41	0.31	0.011	0.25	8.2	24.8
6/17/2019	5013 SATURN	2.64	2.55	0.29	0.007	0.26	8.1	25.4
6/17/2019	119 BUCKINGHAM	2.54	2.47	0.30	0.011	0.27	8.2	25.2
6/17/2019	WALLACE PS	3.20	3.14	0.20	0.006	0.21	8.1	25.6
6/17/2019	1980 FOREST	2.34	2.25	0.35	0.011	0.27	8.2	25.5
6/17/2019	FOREST TOWER	2.54	2.49	0.30	0.008	0.28	8.1	25.1
6/17/2019	LAWLER TOWER	2.94	2.93	0.17	0.006	0.27	8.1	26.9
6/21/2019	3021 WAGON WHEEL	2.60	2.59	0.28	0.007	0.28	8.1	25.2
6/21/2019	FIREWHEEL PS	2.98	2.93	0.23	0.007	0.30	8.2	26.4
6/21/2019	498 CANTERBURY	2.53	2.49	0.30	0.007	0.28	8.2	25.7
6/21/2019	1902 PLEASANT VALLEY	2.68	2.64	0.26	0.010	0.31	8.2	25.6
6/21/2019	LAVON PS	3.10	3.06	0.15	0.007	0.28	8.2	26.2
6/21/2019	BROADWAY PS	2.96	2.93	0.20	0.007	0.32	8.1	26.9
6/21/2019	4301 BROADWAY	2.79	2.74	0.23	0.008	0.30	8.1	26.9
6/21/2019	5626 LYONS	2.32	2.25	0.33	0.016	0.32	8.2	26.2
6/21/2019	1538 E I30	2.27	2.27	0.32	0.023	0.34	8.2	26.3
6/21/2019	1426 COMMERCE	2.94	2.93	0.17	0.006	0.31	8.1	26.8
6/21/2019	COMMERCE TOWER	3.01	2.96	0.19	0.006	0.27	8.1	26.7
6/25/2019	APOLLO PS	3.13	3.04	0.14	0.007	0.29	8.2	23.3
6/25/2019	7602 N JUPITER	2.62	2.58	0.21	0.007	0.30	8.2	24.6

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
6/25/2019	1301 JUPITER	2.48	2.38	0.28	0.008	0.27	8.1	24.3
6/25/2019	2218 S JUPITER	2.31	2.26	0.24	0.023	0.25	8.1	24.8
6/25/2019	5013 SATURN	2.29	2.26	0.28	0.014	0.28	8.2	24.8
6/25/2019	WALLACE PS	2.96	2.94	0.14	0.007	0.26	8.2	25.0
6/25/2019	1980 FOREST	2.50	2.49	0.23	0.010	0.31	8.2	23.4
6/25/2019	FOREST TOWER	2.68	2.63	0.23	0.008	0.27	8.2	23.1
6/25/2019	LAWLER TOWER	2.69	2.69	0.24	0.006	0.28	8.1	24.8
6/26/2019	3021 WAGON WHEEL	2.43	2.40	0.25	0.013	0.26	8.3	24.4
6/26/2019	FIREWHEEL PS	2.88	2.85	0.13	0.006	0.26	8.2	25.0
6/26/2019	498 CANTERBURY	2.32	2.35	0.25	0.008	0.26	8.2	24.5
6/26/2019	1902 PLEASANT VALLEY	2.21	2.24	0.28	0.022	0.31	8.1	24.1
6/26/2019	LAVON PS	2.95	2.99	0.13	0.008	0.27	8.3	24.7
6/26/2019	BROADWAY PS	2.93	2.29	0.17	0.008	0.26	8.3	24.8
6/26/2019	4301 BROADWAY	2.79	2.79	0.18	0.010	0.27	8.3	23.3
6/26/2019	5626 LYONS	2.39	2.37	0.25	0.034	0.26	8.3	22.0
6/26/2019	1538 E I30	2.28	2.25	0.25	0.037	0.26	8.2	22.8
6/26/2019	1426 COMMERCE	2.39	2.35	0.29	0.009	0.27	8.2	24.5
6/26/2019	COMMERCE TOWER	2.55	2.56	0.21	0.008	0.27	8.2	24.2
7/1/2019	APOLLO PS	3.52	3.39	0.10	0.008	0.33	8.4	27.9
7/1/2019	7602 N JUPITER	2.60	2.55	0.20	0.007	0.34	8.1	27.8
7/1/2019	1301 JUPITER	2.50	2.35	0.26	0.008	0.32	8.1	27.0
7/1/2019	2218 S JUPITER	2.15	2.13	0.20	0.045	0.50	8.1	27.4
7/1/2019	5013 SATURN	2.18	2.18	0.26	0.025	0.34	8.1	27.5
7/1/2019	119 BUCKINGHAM	2.13	2.13	0.28	0.069	0.40	8.1	26.7
7/1/2019	WALLACE PS	2.60	2.65	0.24	0.005	0.33	8.1	28.1
7/1/2019	1980 FOREST	2.51	2.50	0.18	0.022	0.30	8.2	26.3
7/1/2019	LAWLER TOWER	3.10	3.09	0.17	0.007	0.34	8.2	27.9
7/2/2019	3021 WAGON WHEEL	2.89	2.81	0.27	0.022	0.11	8.2	26.3
7/2/2019	FIREWHEEL PS	3.18	3.08	0.24	0.007	0.14	8.2	27.9
7/2/2019	498 CANTERBURY	2.76	2.70	0.27	0.009	0.15	8.2	27.5
7/2/2019	1902 PLEASANT VALLEY	2.28	2.24	0.24	0.045	0.18	8.1	26.8
7/2/2019	LAVON PS	3.20	3.16	0.22	0.009	0.13	8.3	28.1
7/2/2019	BROADWAY PS	3.00	3.01	0.23	0.009	0.10	8.2	28.0

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
7/2/2019	4301 BROADWAY	2.93	2.91	0.23	0.016	0.13	8.2	28.0
7/2/2019	5626 LYONS	2.30	2.27	0.24	0.067	0.19	8.1	27.0
7/2/2019	1538 E I30	2.23	2.16	0.26	0.071	0.21	8.1	27.2
7/2/2019	1426 COMMERCE	2.73	2.52	0.26	0.034	0.13	8.2	27.7
7/2/2019	COMMERCE TOWER	2.61	2.53	0.25	0.020	0.14	8.2	27.8
7/5/2019	APOLLO PS	3.00	2.98	0.17	0.003	0.16	7.8	27.3
7/5/2019	WALLACE PS	2.66	2.61	0.22	0.004	0.16	7.8	25.2
7/5/2019	LAWLER TOWER	2.75	2.72	0.20	0.004	0.13	7.9	27.7
7/5/2019	FIREWHEEL PS	3.03	2.99	0.17	0.006	0.16	7.9	25.2
7/5/2019	LAVON PS	2.64	2.59	0.24	0.004	0.17	8.0	24.5
7/5/2019	BROADWAY PS	2.72	2.65	0.25	0.009	0.20	8.0	25.0
7/5/2019	COMMERCE TOWER	2.60	2.50	0.29	0.024	0.18	8.0	24.5
7/8/2019	APOLLO PS	2.99	2.94	0.16	0.003	0.08	7.6	26.3
7/8/2019	7602 N JUPITER	2.78	2.77	0.19	0.009	0.12	8.1	26.3
7/8/2019	1301 JUPITER	2.52	2.52	0.34	0.008	0.10	8.0	26.1
7/8/2019	2218 S JUPITER	2.22	2.17	0.21	0.078	0.18	8.0	24.8
7/8/2019	5013 SATURN	2.62	2.61	0.18	0.040	0.12	8.2	25.8
7/8/2019	119 BUCKINGHAM	2.36	2.32	0.18	0.068	0.15	7.9	24.8
7/8/2019	WALLACE PS	3.05	3.03	0.22	0.007	0.10	8.2	25.4
7/8/2019	1980 FOREST	2.66	2.63	0.17	0.047	0.08	8.0	24.6
7/8/2019	LAWLER TOWER	2.79	2.76	0.21	0.005	0.10	7.8	26.1
7/11/2019	3021 WAGON WHEEL	2.44	2.37	0.22	0.077	0.17	8.0	24.9
7/11/2019	FIREWHEEL PS	3.00	3.00	0.18	0.006	0.15	8.0	26.0
7/11/2019	498 CANTERBURY	2.66	2.58	0.30	0.009	0.10	8.1	25.3
7/11/2019	1902 PLEASANT VALLEY	2.29	2.28	0.18	0.096	0.22	8.0	24.7
7/11/2019	LAVON PS	2.68	2.61	0.28	0.007	0.11	8.1	24.8
7/11/2019	BROADWAY PS	2.59	2.49	0.29	0.007	0.10	8.0	25.4
7/11/2019	4301 BROADWAY	2.63	2.57	0.27	0.013	0.11	8.0	25.2
7/11/2019	5626 LYONS	2.03	2.00	0.20	0.145	0.29	7.9	24.5
7/11/2019	1538 E I30	2.01	1.97	0.18	0.141	0.28	7.9	24.8
7/11/2019	1426 COMMERCE	2.52	2.44	0.34	0.054	0.15	8.1	24.8
7/11/2019	COMMERCE TOWER	2.87	2.83	0.24	0.021	0.13	8.1	24.3
7/12/2019	APOLLO PS	3.27	3.35	0.15	0.008	0.12	8.5	26.7

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
7/12/2019	WALLACE PS	2.94	2.94	0.21	0.011	0.10	8.4	27.0
7/12/2019	LAWLER TOWER	3.32	3.15	0.21	0.009	0.10	8.5	24.1
7/12/2019	FIREWHEEL PS	3.01	3.07	0.16	0.007	0.11	8.2	27.0
7/12/2019	LAVON PS	3.06	3.05	0.17	0.009	0.10	8.4	26.7
7/12/2019	BROADWAY PS	2.95	2.97	0.22	0.010	0.10	8.4	26.8
7/12/2019	COMMERCE TOWER	2.28	2.23	0.29	0.065	0.20	8.0	26.3
7/15/2019	APOLLO PS	3.46	3.38	0.24	0.008	0.10	8.2	26.8
7/15/2019	7602 N JUPITER	3.20	3.18	0.20	0.015	0.20	8.3	27.0
7/15/2019	1301 JUPITER	3.31	3.25	0.19	0.010	0.15	8.3	25.8
7/15/2019	2218 S JUPITER	2.48	2.52	0.19	N/A	0.25	8.2	24.3
7/15/2019	5013 SATURN	2.79	2.85	0.24	0.046	0.18	8.4	24.7
7/15/2019	119 BUCKINGHAM	2.15	2.09	0.16	N/A	0.33	8.2	25.2
7/15/2019	WALLACE PS	3.15	3.17	0.20	0.011	0.14	8.3	26.0
7/15/2019	1980 FOREST	2.88	2.83	0.22	0.083	0.20	8.3	25.4
7/15/2019	FOREST TOWER	3.08	3.01	0.23	0.026	0.14	8.4	24.3
7/15/2019	LAWLER TOWER	3.45	3.39	0.21	0.009	0.12	8.4	26.4
7/22/2019	APOLLO PS	3.41	3.41	0.19	0.008	0.14	8.4	29.5
7/22/2019	7602 N JUPITER	3.23	3.22	0.22	0.028	0.20	8.5	29.6
7/22/2019	1301 JUPITER	2.99	2.97	0.26	0.010	0.15	8.5	29.2
7/22/2019	2218 S JUPITER	2.50	2.46	0.18	0.180	0.28	8.3	29.1
7/22/2019	5013 SATURN	2.58	2.52	0.30	0.088	0.20	8.4	29.0
7/22/2019	119 BUCKINGHAM	2.50	2.46	0.21	0.157	0.30	8.4	29.2
7/22/2019	WALLACE PS	3.06	2.99	0.29	0.014	0.15	8.5	29.1
7/22/2019	1980 FOREST	2.62	2.65	0.17	0.187	0.27	8.4	28.8
7/22/2019	FOREST TOWER	2.13	2.14	0.23	0.146	0.23	8.4	28.8
7/22/2019	LAWLER TOWER	3.28	3.22	0.21	0.012	0.12	8.5	29.7
7/23/2019	3021 WAGON WHEEL	2.55	2.52	0.15	0.146	0.27	8.2	26.5
7/23/2019	FIREWHEEL PS	3.34	3.26	0.20	0.009	0.10	8.4	27.2
7/23/2019	498 CANTERBURY	3.02	3.01	0.24	0.018	0.11	8.4	27.5
7/23/2019	1902 PLEASANT VALLEY	2.33	2.15	0.20	0.205	0.32	8.2	27.2
7/23/2019	LAVON PS	3.04	3.00	0.25	0.009	0.09	8.4	27.2
7/23/2019	BROADWAY PS	2.98	2.96	0.28	0.013	0.11	8.4	28.8
7/23/2019	4301 BROADWAY	2.78	2.79	0.23	0.054	0.12	8.3	28.5

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
7/23/2019	5626 LYONS	2.16	2.14	0.12	0.276	0.40	8.2	28.1
7/23/2019	1538 E I30	2.09	2.03	0.11	0.296	0.50	8.1	28.1
7/23/2019	1426 COMMERCE	2.73	2.70	0.18	0.124	0.19	8.2	27.9
7/23/2019	COMMERCE TOWER	2.88	2.63	0.25	0.071	0.09	8.2	28.1
7/25/2019	APOLLO PS	3.07	2.97	0.25	0.007	0.07	8.1	28.9
7/25/2019	WALLACE PS	2.97	2.91	0.22	0.008	0.08	8.1	28.8
7/25/2019	FOREST TOWER	1.36	1.35	0.26	0.167	0.39	8.2	26.8
7/25/2019	LAWLER TOWER	2.84	2.73	0.20	0.007	0.12	8.2	28.9
7/25/2019	FIREWHEEL PS	3.05	3.00	0.28	0.006	0.08	8.0	29.4
7/25/2019	LAVON PS	2.96	2.86	0.29	0.007	0.10	8.2	28.9
7/25/2019	BROADWAY PS	2.80	2.79	0.34	0.010	0.07	8.1	28.7
7/25/2019	COMMERCE TOWER	2.50	2.53	0.23	0.083	0.17	7.9	28.6
7/29/2019	APOLLO PS	3.08	3.06	0.18	0.006	0.08	7.8	28.9
7/29/2019	7602 N JUPITER	2.72	2.67	0.24	0.031	0.13	8.0	29.0
7/29/2019	1301 JUPITER	2.63	2.57	0.37	0.007	0.09	8.0	28.9
7/29/2019	2218 S JUPITER	1.67	1.65	0.26	0.133	0.33	7.9	28.6
7/29/2019	5013 SATURN	2.14	2.01	0.28	0.052	0.10	7.9	28.7
7/29/2019	119 BUCKINGHAM	2.41	2.41	0.19	0.105	0.15	8.0	28.5
7/29/2019	WALLACE PS	2.70	2.66	0.26	0.008	0.07	8.1	28.5
7/29/2019	1980 FOREST	1.90	1.81	0.22	0.190	0.29	7.8	28.0
7/29/2019	FOREST TOWER	2.24	2.23	0.20	0.134	0.36	7.9	30.5
7/29/2019	LAWLER TOWER	2.80	2.75	0.38	0.006	0.09	7.9	28.9
7/30/2019	3021 WAGON WHEEL	1.92	1.83	0.19	0.174	0.32	8.0	27.2
7/30/2019	FIREWHEEL PS	2.98	3.01	0.22	0.006	0.06	8.0	27.7
7/30/2019	498 CANTERBURY	2.64	2.59	0.26	0.027	0.08	8.0	27.8
7/30/2019	1902 PLEASANT VALLEY	1.91	1.88	0.31	0.096	0.23	7.9	28.1
7/30/2019	LAVON PS	2.65	2.59	0.29	0.006	0.07	8.1	28.2
7/30/2019	BROADWAY PS	2.76	2.71	0.29	0.011	0.07	8.1	28.4
7/30/2019	4301 BROADWAY	2.55	2.48	0.33	0.028	0.12	8.0	28.7
7/30/2019	5626 LYONS	1.25	1.14	0.21	0.239	0.49	7.7	28.6
7/30/2019	1538 E I30	1.44	1.40	0.21	0.216	0.51	7.6	29.0
7/30/2019	1426 COMMERCE	2.40	2.32	0.36	0.040	0.11	7.9	28.9
7/30/2019	COMMERCE TOWER	2.49	2.41	0.29	0.025	0.11	7.9	28.7

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
8/5/2019	APOLLO PS	3.03	3.04	0.23	0.007	0.06	7.9	29.2
8/5/2019	7602 N JUPITER	2.88	2.90	0.31	0.057	0.16	8.1	28.8
8/5/2019	1301 JUPITER	2.75	2.76	0.34	0.010	0.10	8.0	30.0
8/5/2019	2218 S JUPITER	1.95	1.96	0.34	0.234	0.40	8.0	29.1
8/5/2019	5013 SATURN	2.41	2.40	0.24	0.137	0.21	8.3	28.6
8/5/2019	119 BUCKINGHAM	2.60	2.59	0.20	0.139	0.24	8.0	28.0
8/5/2019	WALLACE PS	2.94	2.96	0.30	0.011	0.05	8.2	28.6
8/5/2019	1980 FOREST	2.22	2.21	0.15	0.254	0.40	8.0	28.4
8/5/2019	FOREST TOWER	2.56	2.55	0.15	0.155	0.18	8.1	28.1
8/5/2019	LAWLER TOWER	2.94	2.96	0.29	0.009	0.07	8.0	29.5
8/8/2019	3021 WAGON WHEEL	1.72	1.61	0.19	0.199	0.32	7.9	28.2
8/8/2019	FIREWHEEL PS	2.71	2.87	0.25	0.008	0.05	8.2	29.2
8/8/2019	498 CANTERBURY	2.53	2.52	0.28	0.034	0.07	8.1	28.5
8/8/2019	1902 PLEASANT VALLEY	2.27	2.25	0.28	0.041	0.12	7.9	28.6
8/8/2019	LAVON PS	2.65	2.65	0.28	0.009	0.05	8.1	28.9
8/8/2019	BROADWAY PS	4.34	4.39	0.29	0.016	0.05	8.3	29.6
8/8/2019	4301 BROADWAY	4.55	4.60	0.17	0.022	0.05	8.3	29.0
8/8/2019	5626 LYONS	2.36	2.28	0.31	0.131	0.27	7.7	28.7
8/8/2019	1538 E I30	1.36	1.24	0.35	0.192	0.53	7.5	29.1
8/8/2019	1426 COMMERCE	4.17	4.24	0.15	0.044	0.06	8.2	29.6
8/8/2019	COMMERCE TOWER	2.53	2.54	0.27	0.020	0.12	8.0	29.8
8/9/2019	APOLLO PS	2.98	2.99	0.22	0.008	0.07	7.9	28.9
8/9/2019	WALLACE PS	2.64	2.67	0.24	0.009	0.06	8.1	27.9
8/9/2019	FOREST TOWER	2.32	2.33	0.12	0.134	0.14	7.9	28.6
8/9/2019	LAWLER TOWER	2.52	2.53	0.25	0.015	0.06	8.0	29.1
8/9/2019	FIREWHEEL PS	2.78	2.84	0.23	0.007	0.05	8.0	29.3
8/9/2019	LAVON PS	2.45	2.48	0.30	0.008	0.02	8.0	28.7
8/9/2019	BROADWAY PS	4.62	4.60	0.00	0.010	0.08	8.1	28.7
8/9/2019	COMMERCE TOWER	2.40	2.40	0.32	0.018	0.05	8.0	28.7
8/12/2019	APOLLO PS	3.22	3.20	0.22	0.008	0.02	8.3	29.1
8/12/2019	7602 N JUPITER	2.89	2.93	0.21	0.072	0.11	8.4	29.1
8/12/2019	1301 JUPITER	2.85	2.88	0.28	0.012	0.07	8.5	28.7
8/12/2019	2218 S JUPITER	2.10	2.08	0.17	0.251	0.40	8.2	28.5

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
8/12/2019	5013 SATURN	2.15	2.16	0.25	0.131	0.15	8.1	28.6
8/12/2019	119 BUCKINGHAM	2.79	2.81	0.19	0.148	0.18	8.4	28.9
8/12/2019	WALLACE PS	3.01	3.05	0.23	0.013	0.02	8.5	28.1
8/12/2019	1980 FOREST	2.25	2.31	0.11	0.281	0.35	8.2	28.7
8/12/2019	FOREST TOWER	2.70	2.71	0.15	0.191	0.22	8.4	28.3
8/12/2019	LAWLER TOWER	3.00	3.00	0.27	0.016	0.05	8.4	29.2
8/14/2019	3021 WAGON WHEEL	2.00	2.00	0.13	0.263	0.35	8.0	28.0
8/14/2019	FIREWHEEL PS	3.24	3.26	0.19	0.009	0.06	7.9	24.5
8/14/2019	498 CANTERBURY	2.84	2.89	0.18	0.070	0.08	8.0	29.4
8/14/2019	1902 PLEASANT VALLEY	2.50	2.50	0.22	0.090	0.12	8.0	29.2
8/14/2019	LAVON PS	3.10	3.14	0.19	0.010	0.06	8.1	29.8
8/14/2019	BROADWAY PS	2.88	2.92	0.25	0.016	0.06	8.2	29.7
8/14/2019	4301 BROADWAY	2.80	2.81	0.24	0.029	0.07	8.1	29.6
8/14/2019	5626 LYONS	1.72	1.75	0.16	0.218	0.39	7.8	29.3
8/14/2019	1538 E I30	1.95	1.96	0.21	0.186	0.31	7.8	29.1
8/14/2019	1426 COMMERCE	2.63	2.68	0.18	0.072	0.11	8.0	29.5
8/14/2019	COMMERCE TOWER	2.93	2.92	0.21	0.032	0.08	8.0	29.8
8/16/2019	APOLLO PS	3.13	3.06	0.28	0.008	0.07	7.9	29.9
8/16/2019	WALLACE PS	2.98	2.99	0.27	0.011	0.03	8.3	29.9
8/16/2019	FOREST TOWER	2.35	2.37	0.14	0.252	0.29	8.3	29.0
8/16/2019	LAWLER TOWER	2.96	3.00	0.33	0.009	0.08	8.1	29.9
8/16/2019	FIREWHEEL PS	3.02	3.05	0.25	0.009	0.05	8.2	30.2
8/16/2019	LAVON PS	3.20	3.21	0.19	0.011	0.06	8.2	30.0
8/16/2019	BROADWAY PS	2.89	2.95	0.32	0.016	0.07	8.5	30.4
8/16/2019	COMMERCE TOWER	2.71	2.75	0.22	0.098	0.13	8.2	30.1
8/20/2019	APOLLO PS	3.04	3.00	0.20	0.006	0.07	7.6	29.3
8/20/2019	7602 N JUPITER	2.55	2.56	0.22	0.058	0.14	7.9	30.0
8/20/2019	1301 JUPITER	2.40	2.45	0.34	0.008	0.06	8.0	29.2
8/20/2019	2218 S JUPITER	2.01	1.98	0.26	0.204	0.28	8.0	29.5
8/20/2019	5013 SATURN	2.26	2.30	0.23	0.071	0.12	8.1	28.9
8/20/2019	119 BUCKINGHAM	2.53	2.54	0.19	0.141	0.16	8.0	28.8
8/20/2019	WALLACE PS	2.80	2.85	0.26	0.011	0.08	8.2	28.8
8/20/2019	1980 FOREST	2.12	2.12	0.17	0.228	0.33	8.1	29.2

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
8/20/2019	FOREST TOWER	2.15	2.15	0.20	0.162	0.23	8.1	28.3
8/20/2019	LAWLER TOWER	2.80	2.80	0.23	0.008	0.08	7.8	29.7
8/21/2019	3021 WAGON WHEEL	1.57	1.48	0.16	0.260	0.38	7.8	28.8
8/21/2019	FIREWHEEL PS	2.90	2.87	0.24	0.006	0.06	7.8	29.5
8/21/2019	498 CANTERBURY	2.54	2.45	0.26	0.059	0.12	7.8	29.3
8/21/2019	1902 PLEASANT VALLEY	1.78	1.79	0.20	0.069	0.12	8.0	28.9
8/21/2019	LAVON PS	3.35	3.39	0.20	0.010	0.05	8.1	29.4
8/21/2019	BROADWAY PS	2.68	2.71	0.33	0.012	0.08	7.9	29.6
8/21/2019	4301 BROADWAY	2.71	2.71	0.32	0.029	0.09	7.9	29.9
8/21/2019	5626 LYONS	1.11	1.13	0.20	0.259	0.56	7.7	29.5
8/21/2019	1426 COMMERCE	2.78	2.78	0.22	0.058	0.11	8.0	29.7
8/21/2019	COMMERCE TOWER	2.80	2.85	0.25	0.035	0.09	8.0	29.3
8/22/2019	4301 BROADWAY	1.44	1.42	0.22	0.227	0.00	7.7	29.7
8/23/2019	APOLLO PS	2.96	2.96	0.33	0.006	0.06	7.7	29.4
8/23/2019	WALLACE PS	2.89	2.95	0.31	0.008	0.06	7.9	29.5
8/23/2019	FOREST TOWER	2.09	2.00	0.26	0.145	0.22	7.8	29.5
8/23/2019	LAWLER TOWER	2.54	2.53	0.32	0.020	0.07	8.0	29.5
8/23/2019	FIREWHEEL PS	3.01	2.97	0.29	0.006	0.05	7.8	29.6
8/23/2019	LAVON PS	3.07	3.12	0.25	0.012	0.06	8.0	28.8
8/23/2019	BROADWAY PS	3.52	3.56	0.30	0.013	0.08	8.0	30.0
8/23/2019	COMMERCE TOWER	2.96	2.96	0.25	0.043	0.09	7.9	29.4
8/26/2019	APOLLO PS	3.26	3.32	0.24	0.009	0.08	8.6	30.0
8/26/2019	7602 N JUPITER	2.55	2.57	0.21	0.136	0.19	8.1	31.0
8/26/2019	1301 JUPITER	2.79	2.85	0.31	0.010	0.06	8.2	29.5
8/26/2019	2218 S JUPITER	1.52	1.53	0.18	0.277	0.45	8.0	28.9
8/26/2019	5013 SATURN	2.29	2.33	0.22	0.095	0.14	8.1	29.3
8/26/2019	119 BUCKINGHAM	2.30	2.33	0.21	0.211	0.29	8.0	29.9
8/26/2019	WALLACE PS	2.66	2.76	0.35	0.010	0.06	8.2	29.5
8/26/2019	1980 FOREST	1.86	1.87	0.19	0.250	0.33	8.0	29.8
8/26/2019	FOREST TOWER	2.25	2.26	0.17	0.225	0.29	8.0	30.2
8/26/2019	LAWLER TOWER	2.52	2.55	0.41	0.023	0.08	8.2	30.2
8/27/2019	7602 N JUPITER	2.89	2.92	0.21	0.123	0.12	8.5	29.3
8/27/2019	2218 S JUPITER	2.32	2.36	0.18	0.212	0.20	8.4	29.2

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
8/27/2019	5013 SATURN	2.11	2.13	0.21	0.170	0.16	8.2	29.1
8/27/2019	119 BUCKINGHAM	2.59	2.64	0.18	0.222	0.25	8.4	29.2
8/27/2019	1980 FOREST	1.70	1.72	0.26	0.213	0.35	8.1	29.3
8/27/2019	FOREST TOWER	2.34	2.30	0.15	0.279	0.28	8.3	29.4
8/28/2019	3021 WAGON WHEEL	1.41	1.47	0.27	0.375	0.59	8.1	29.2
8/28/2019	FIREWHEEL PS	2.94	2.97	0.24	0.011	0.10	8.4	29.8
8/28/2019	498 CANTERBURY	2.50	2.50	0.26	0.124	0.21	8.3	29.2
8/28/2019	1902 PLEASANT VALLEY	1.96	1.95	0.18	0.286	0.46	8.1	28.6
8/28/2019	LAVON PS	2.87	2.92	0.21	0.017	0.10	8.5	29.0
8/28/2019	BROADWAY PS	3.95	3.98	0.23	0.016	0.10	8.4	29.9
8/28/2019	4301 BROADWAY	3.83	3.93	0.13	0.042	0.12	8.4	29.7
8/28/2019	5626 LYONS	2.14	2.13	0.12	0.319	0.44	8.0	29.8
8/28/2019	1538 E I30	1.99	2.02	0.13	0.331	0.52	8.0	29.8
8/28/2019	1426 COMMERCE	2.73	2.79	0.25	0.052	0.09	8.5	29.6
8/28/2019	COMMERCE TOWER	2.63	2.52	0.28	0.009	0.14	8.3	29.5
9/3/2019	APOLLO PS	3.15	3.12	0.12	0.009	0.07	8.4	29.8
9/3/2019	7602 N JUPITER	3.68	2.71	0.28	0.086	0.14	8.2	30.5
9/3/2019	1301 JUPITER	2.73	2.79	0.19	0.009	0.07	8.2	31.0
9/3/2019	2218 S JUPITER	1.60	1.62	0.16	0.218	0.41	7.9	30.1
9/3/2019	119 BUCKINGHAM	2.54	2.55	0.11	0.162	0.19	8.2	29.5
9/3/2019	WALLACE PS	2.95	2.98	0.18	0.011	0.08	8.2	29.2
9/3/2019	1980 FOREST	1.93	1.92	0.17	0.181	0.30	8.0	29.5
9/3/2019	FOREST TOWER	2.23	2.16	0.14	0.164	0.22	8.1	28.9
9/3/2019	LAWLER TOWER	2.85	2.92	0.17	0.014	0.09	8.3	30.1
9/4/2019	3021 WAGON WHEEL	1.44	1.40	0.12	0.313	0.59	8.0	29.9
9/4/2019	FIREWHEEL PS	3.01	2.97	0.19	0.012	0.11	8.4	30.0
9/4/2019	498 CANTERBURY	2.64	2.67	0.20	0.084	0.18	8.4	29.5
9/4/2019	1902 PLEASANT VALLEY	2.51	2.49	0.12	0.130	0.21	8.2	29.3
9/4/2019	LAVON PS	3.09	3.09	0.18	0.013	0.07	8.4	28.7
9/4/2019	BROADWAY PS	4.11	4.11	0.08	0.016	0.10	8.5	29.5
9/4/2019	4301 BROADWAY	4.01	4.10	0.08	0.023	0.08	8.5	29.6
9/4/2019	5626 LYONS	2.30	2.30	0.13	0.183	0.31	8.1	29.6
9/4/2019	1538 E I30	2.62	2.57	0.08	0.198	0.26	8.1	28.7

**City of Garland Water Quality Samples
January 4, 2019 – Present**

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
9/4/2019	1426 COMMERCE	3.51	3.61	0.07	0.071	0.14	8.4	29.5
9/4/2019	COMMERCE TOWER	2.51	2.56	0.18	0.066	0.14	8.2	29.5
9/5/2019	APOLLO PS	2.68	2.64	0.21	0.007	0.07	8.2	29.4
9/5/2019	WALLACE PS	2.78	2.76	0.30	0.012	0.12	8.3	29.9
9/5/2019	FOREST TOWER	2.36	2.35	0.17	0.194	0.21	8.1	29.6
9/5/2019	LAWLER TOWER	2.82	2.84	0.27	0.021	0.09	8.3	29.4
9/5/2019	FIREWHEEL PS	2.82	2.81	0.20	0.010	0.07	8.3	29.3
9/5/2019	LAVON PS	2.95	2.90	0.27	0.015	0.06	8.4	29.5
9/5/2019	BROADWAY PS	3.91	3.91	0.15	0.018	0.08	8.3	26.9
9/5/2019	COMMERCE TOWER	2.87	2.87	0.19	0.046	0.10	8.3	29.9
9/9/2019	APOLLO PS	2.58	2.57	0.29	0.008	0.09	7.9	29.8
9/9/2019	7602 N JUPITER	2.11	2.10	0.23	0.092	0.15	7.9	30.4
9/9/2019	1301 JUPITER	1.95	1.90	0.42	0.007	0.05	7.9	31.0
9/9/2019	2218 S JUPITER	1.21	1.15	0.25	0.198	0.37	7.8	29.5
9/9/2019	5013 SATURN	1.09	1.07	0.34	0.162	0.34	7.7	29.9
9/9/2019	119 BUCKINGHAM	2.00	1.95	0.17	0.197	0.24	7.9	29.6
9/9/2019	WALLACE PS	2.39	2.34	0.32	0.010	0.04	7.9	29.5
9/9/2019	1980 FOREST	1.46	1.42	0.24	0.186	0.32	7.7	30.3
9/9/2019	FOREST TOWER	1.82	1.80	0.19	0.194	0.23	7.8	30.1
9/9/2019	LAWLER TOWER	2.34	2.29	0.27	0.019	0.07	7.8	29.8
9/10/2019	3021 WAGON WHEEL	0.90	0.88	0.18	0.274	0.50	7.6	30.3
9/10/2019	FIREWHEEL PS	2.45	2.46	0.23	0.006	0.07	7.8	30.2
9/10/2019	498 CANTERBURY	2.07	2.07	0.25	0.047	0.12	7.8	29.5
9/10/2019	1902 PLEASANT VALLEY	1.53	1.54	0.29	0.158	0.30	7.7	29.7
9/10/2019	LAVON PS	2.30	2.31	0.26	0.008	0.07	8.0	28.6
9/10/2019	BROADWAY PS	3.97	3.93	0.12	0.010	0.07	7.8	29.7
9/10/2019	4301 BROADWAY	2.64	2.63	0.19	0.015	0.08	7.7	29.8
9/10/2019	5626 LYONS	1.48	1.47	0.28	0.102	0.24	7.7	29.9
9/10/2019	1538 E I30	1.50	1.49	0.31	0.099	0.20	7.7	29.9
9/10/2019	1426 COMMERCE	1.56	1.55	0.28	0.129	0.24	7.7	29.9
9/10/2019	COMMERCE TOWER	2.06	2.05	0.27	0.052	0.14	7.8	29.3
9/13/2019	APOLLO PS	3.11	3.08	0.17	0.007	0.06	8.0	29.1
9/13/2019	WALLACE PS	2.88	2.91	0.27	0.021	0.06	8.2	29.2

City of Garland Water Quality Samples
January 4, 2019 – Present

Date	Location	TotalCL2	Monochloramine	Free Ammonia	Nitrite	Nitrate	pH	Temp C*
9/13/2019	FOREST TOWER	1.84	1.80	0.20	0.249	0.28	8.2	29.7
9/13/2019	LAWLER TOWER	2.93	2.87	0.24	0.015	0.04	8.1	29.3
9/13/2019	FIREWHEEL PS	3.07	3.02	0.16	0.010	0.02	8.3	29.3
9/13/2019	LAVON PS	3.14	3.14	0.15	0.009	0.05	8.1	29.3
9/13/2019	BROADWAY PS	3.90	3.89	0.26	0.017	0.01	8.3	30.1
9/13/2019	COMMERCE TOWER	2.79	2.80	0.23	0.033	0.08	8.2	29.7